

Day	Operation Hours	HF			O2	Sadržaj vlage	T	P	Brzina	Protok	Kolic. Otp. gasa	
		mg/Nm <sup>3</sup>	kg/h	Limit								
01.04.	20.5	0.19	0.03	5.00	13.30	0.01	45.53	1004.31	13.16	153236.88	3141.38	
02.04.	0.5	0.04	0.01	5.00	13.31	0.02	30.43	1004.72	11.83	144744.64	72.37	
03.04.	12.5	0.09	0.02	5.00	14.26	0.01	48.79	999.16	14.38	164891.03	2061.13	
04.04.	23.0	0.10	0.02	5.00	14.43	0.00	51.73	996.95	14.64	165993.71	3817.87	
05.04.	24.0	0.14	0.02	5.00	14.52	0.00	52.95	993.76	15.12	170380.39	4089.14	
06.04.	24.0	0.15	0.02	5.00	14.48	0.00	52.93	996.30	14.78	166885.50	4005.23	
07.04.	24.0	0.22	0.04	5.00	14.51	0.00	53.07	994.83	14.60	164572.35	3949.72	
08.04.	15.5	0.24	0.04	5.00	14.29	0.00	48.45	993.44	13.97	159454.75	2471.53	
09.04.	24.0	0.11	0.02	5.00	14.45	0.00	52.85	993.94	13.89	156208.91	3749.03	
10.04.	24.0	0.04	0.01	5.00	14.55	0.00	54.76	993.89	14.69	164329.80	3943.89	
11.04.	24.0	0.05	0.01	5.00	14.49	0.00	54.60	996.71	14.29	160458.02	3850.98	
12.04.	24.0	0.05	0.01	5.00	14.40	0.00	54.05	1000.77	14.53	164395.18	3945.46	
13.04.	15.0	0.04	0.01	5.00	14.10	0.00	47.72	1003.23	14.07	162605.31	2439.11	
14.04.	24.0	0.05	0.01	5.00	14.22	0.00	50.47	1003.44	14.94	171261.49	4110.29	
15.04.	24.0	0.07	0.01	5.00	14.18	0.00	50.09	1005.51	14.40	165571.80	3973.72	
16.04.	24.0	0.08	0.01	5.00	13.78	0.00	50.41	1007.94	14.40	165838.76	3980.13	
17.04.	23.0	0.07	0.01	5.00	13.85	0.00	48.44	1007.79	12.77	147501.83	3392.55	
18.04.	24.0	0.05	0.01	5.00	14.06	0.00	49.50	1013.40	12.73	147235.05	3533.66	
19.04.	22.5	0.03	0.01	5.00	14.11	0.00	51.44	1015.05	13.91	160607.50	3613.66	
20.04.	23.5	0.03	0.00	5.00	13.77	0.00	45.55	1014.67	11.61	136010.56	3196.28	
21.04.	23.5	0.03	0.00	5.00	14.01	0.00	48.08	1010.18	12.58	145657.37	3422.95	
22.04.	24.0	0.04	0.01	5.00	14.26	0.00	51.48	1002.64	14.26	162863.18	3908.71	
23.04.	14.5	0.04	0.01	5.00	14.00	0.00	45.06	1001.25	13.34	155143.01	2249.57	
24.04.	24.0	0.15	0.02	5.00	14.17	0.13	51.19	1004.83	13.78	157606.37	3782.58	
25.04.	16.5	0.17	0.02	5.00	13.93	0.19	46.89	1006.19	12.77	147894.21	2440.24	
26.04.	24.0	0.06	0.01	5.00	14.10	0.05	51.58	1006.14	13.53	154699.06	3712.63	
27.04.	24.0	0.16	0.02	5.00	12.55	0.00	52.37	1004.35	13.98	159279.20	3822.63	
28.04.	24.0	0.15	0.02	5.00	10.92	0.00	53.58	1001.93	14.65	165936.40	3982.56	
29.04.	24.0	0.15	0.02	5.00	10.92	0.00	53.58	1001.93	14.65	165936.40	3982.56	
30.04.	24.0	4.45	0.49	5.00	11.61	1.80	44.87	862.06	12.81	146141.02	3507.44	
MAV Average/ Sum	642.5	0.24	0.03	5.00	13.78	0.07	49.75	998.04	13.84	158444.66	102149.00	
Avalaibility in %		100.0 %	100.0 %	100.0 %	100.0 %	100.0 %	100.0 %	100.0 %	100.0 %	100.0 %	100.0 %	
DAV Min (steady state)		0.03	0.00	5.00	10.92	0.00	30.43	862.06	11.61	136010.56	72.37	
Time		19.04.	20.04.	01.04.	28.04.	04.04.	02.04.	30.04.	20.04.	20.04.	02.04.	
DAV Max (steady state)		4.45	0.49	5.00	14.55	1.80	54.76	1015.05	15.12	171261.49	4110.29	
Time		30.04.	30.04.	01.04.	10.04.	30.04.	10.04.	19.04.	05.04.	14.04.	14.04.	
Uncertainty mass (%)			933.3 %									

Operation Hours: 642.5, Steady Op Hours: 599.0, Availability O2: 100.0 %

Legend  
 Letnje - 'S' ili; zimsko 'W'  
 status postrojenja: Stabilan rad - '-'; Zastoj - '-'; Pokretanje - 'SU'; Zaustavljanje - 'SD'  
 status merjenja: Validno - '-'; Zamenska vrednost - 'S'; Održavanje - 'M'; Kvar - 'X'; Kalibracija - 'C'; Iznad validnog opsega kalibracije - 'P'; Greška - 'F'; Iznad opsega merjenja - 'O'; Ispod opsega merjenja - 'U'; Nema podataka - 'N'  
 Usaglašenost sa GVE: >GVE - 'L'; >GVE+MN - 'I'; >GVE\*1,2 - 'A'; >GVE\*1,2+MN - 'a'; >2\*GVE - 'B'; >2\*GVE+MN - 'b'; Dnevna važeća srednja vrednost>GVE - 'T'; Dnevna važeća srednja vrednost>GVE+MN - 't'  
 MN: HF= 1 mg/m<sup>3</sup>, HCl=6 mg/m<sup>3</sup>, NH3=10 mg/m<sup>3</sup>  
 Created on/ at 16.7.2019./ 11:51:34, created according to ÖNORM M9412:2008 (EmiProtocol, V 6.0.1.0)