

Day	Operation Hours	HF			O2	Sadržaj vlage	T	P	Brzina	Protok	Kolic. Otp. gasa	
		mg/Nm <sup>3</sup>	kg/h	Limit							%	%
01.07.	24.0	3.29	0.45	5.00	7.97	17.07	58.88	1006.32	14.56	135222.55	3245.36	
02.07.	24.0	3.19	0.44	5.00	8.45	17.12	58.88	1002.41	14.81	136936.75	3286.50	
03.07.	24.0	3.33	0.45	5.00	8.66	17.83	59.68	1004.98	14.84	136101.61	3266.47	
04.07.	24.0	2.32	0.31	5.00	7.81	14.33	53.75	1007.22	12.01	113901.88	2733.68	
05.07.	24.0	3.24	0.45	5.00	7.12	17.45	59.19	1005.18	15.05	138858.95	3332.59	
06.07.	24.0	3.44	0.47	5.00	7.98	18.30	60.19	1001.40	14.96	135695.49	3256.72	
07.07.	24.0	2.43	0.32	5.00	8.22	14.61	52.60	997.27	12.63	119782.25	2874.77	
08.07.	18.5	1.12	0.15	5.00	7.76	7.75	40.72	1001.83	9.12	95548.28	1767.65	
09.07.	24.0	4.36	0.66	5.00	7.70	11.26	49.23	1003.47	15.11	153989.24	3695.75	
10.07.	24.0	4.56	0.69	5.00	7.29	49.72	1003.43	15.05	153257.71	3678.15		
11.07.	24.0	4.20	0.65	5.00	7.50	11.75	50.98	1002.69	15.34	154794.19	3715.10	
12.07.	12.5	2.64	0.40	5.00	5.92	9.56	45.28	1002.15	13.03	134229.02	1677.88	
13.07.	24.0	2.44	0.37	5.00	5.62	11.70	49.97	999.80	15.15	152804.04	3667.31	
14.07.	24.0	2.47	0.35	5.00	6.14	12.98	52.41	999.76	14.61	144299.07	3463.17	
15.07.	24.0	2.83	0.40	5.00	6.26	13.15	52.28	1000.58	14.29	141025.02	3384.61	
16.07.	24.0	2.26	0.31	5.00	6.83	12.30	50.90	1001.34	13.61	136373.99	3273.00	
17.07.	24.0	2.24	0.36	5.00	6.72	11.93	50.33	1001.56	16.09	162231.07	3893.54	
18.07.	19.5	2.18	0.36	5.00	6.33	10.27	47.69	1001.48	14.59	148465.45	2895.11	
19.07.	24.0	2.85	0.40	5.00	6.03	12.63	51.70	1005.24	13.82	137925.80	3310.27	
20.07.	24.0	2.35	0.32	5.00	7.54	12.43	50.47	1006.72	13.53	135939.57	3262.60	
21.07.	24.0	2.76	0.32	5.00	7.06	12.86	51.36	1007.32	11.85	118366.04	2840.77	
22.07.	24.0	2.47	0.35	5.00	2.14	11.93	49.70	1009.75	13.08	131083.08	3145.99	
23.07.	15.5	1.11	0.15	5.00	3.33	8.62	43.40	1006.83	13.01	139289.22	2158.97	
24.07.	16.0	0.68	0.10	5.00	0.12	9.71	46.44	1006.33	13.85	145335.41	2325.35	
25.07.	21.5	0.54	0.08	5.00	0.03	9.26	45.76	1006.48	13.87	146766.21	3155.51	
26.07.	24.0	0.59	0.09	5.00	0.43	9.92	46.54	1000.71	15.15	157787.79	3786.94	
27.07.	24.0	0.50	0.07	5.00	1.58	9.76	46.01	994.31	13.32	138128.23	3315.04	
28.07.	24.0	0.43	0.06	5.00	4.59	9.49	45.38	990.58	12.89	134141.01	3219.39	
29.07.	14.5	0.29	0.04	5.00	2.07	8.18	41.88	993.87	12.08	127448.22	1847.98	
30.07.	24.0	0.41	0.05	5.00	0.01	9.55	45.52	998.53	9.83	101963.09	2447.10	
31.07.	23.5	0.43	0.05	5.00	0.77	9.73	45.28	1000.67	10.39	108215.15	2543.05	
MAV Average/ Sum	693.5	2.19	0.31	5.00	5.35	12.09	50.07	1002.26	13.60	135996.95	94466.32	
Avalability in %	100.0 %	100.0 %	100.0 %	100.0 %	100.0 %	100.0 %	100.0 %	100.0 %	100.0 %	100.0 %	100.0 %	
DAV Min (steady state)	0.29	0.04	5.00	0.01	7.75	40.72	990.58	9.12	95548.28	1677.88		
Time	29.07.	29.07.	01.07.	30.07.	08.07.	08.07.	28.07.	08.07.	08.07.	08.07.	12.07.	
DAV Max (steady state)	4.56	0.69	5.00	8.66	18.30	60.19	1009.75	16.09	162231.07	3893.54		
Time	10.07.	10.07.	01.07.	03.07.	06.07.	06.07.	22.07.	17.07.	17.07.	17.07.	17.07.	
Uncertainty mass (%)		90.3 %										

Operation Hours: 693.5, Steady Op Hours: 649.0, Availability O2: 100.0 %

Legend  
 Letnje - 'S' ili; zimsko 'W'  
 status postrojenja: Stabilan rad - ''; Zastoj - '-'; Pokretanje - 'SU'; Zaustavljanje - 'SD'  
 status merenja: Validno - ''; Zamenska vrednost - 'S'; Održavanje - 'M'; Kvar - 'X'; Kalibracija - 'C'; Iznad validnog opsega kalibracije - 'P'; Greška - 'F'; Iznad opsega merenja - 'O'; Ispod opsega merenja - 'U'; Nema podataka - 'N'  
 Usaglašenost sa GVE: >GVE - 'L'; >GVE+MN - 'I'; >GVE\*1,2 - 'A'; >GVE\*1,2+MN - 'a'; >2GVE - 'B'; >2GVE+MN - 'b'; Dnevna važeća srednja vrednost>GVE - 'T'; Dnevna važeća srednja vrednost>GVE+MN - 't'  
 MN: HF= 1 mg/m<sup>3</sup>; HCl=6 mg/m<sup>3</sup>; NH3=10 mg/m<sup>3</sup>  
 Created on/ at 13.8.2019./ 10:59:28, created according to ÖNORM M9412:2008 (EmiProtocol, V 6.0.1.0)