

Day	Operation Hours	HF			HCl			NH3			O2	Sadržaj vlage	T	P	Brzina	Protok	Kolic. Otp. gasa
		mg/Nm ³	kg/h	Limit	mg/Nm ³	kg/h	Limit	mg/Nm ³	kg/h	Limit							
01.11.	18.5	0.08	0.00	5.00	0.00	0.00	30.00	16.75	0.00	30.00	24.43	15.87	57.34	1009.96	0.00	0.00	0.00
02.11.	16.5	0.04	0.00	5.00	0.00	0.00	30.00	10.20	0.04	30.00	23.14	17.30	59.58	999.38	0.16	1374.14	22.67
03.11.	23.0	0.07	0.00	5.00	0.00	0.00	30.00	8.64	0.00	30.00	25.07	19.33	61.94	991.47	0.00	0.00	0.00
04.11.	23.5	1.72	0.00	5.00	0.00	0.00	30.00	11.33	0.00	30.00	23.68	19.12	63.26	988.67	0.00	0.00	0.00
05.11.	10.5	1.39	0.00	5.00	0.00	0.00	30.00	2.29	0.00	30.00	21.48	12.38	50.60	991.60	0.00	0.00	0.00
06.11.	23.0	2.56	0.00	5.00	0.00	0.00	30.00	4.97	0.00	30.00	20.19	7.53	45.07	993.25	0.00	0.00	0.00
07.11.	24.0	1.86	0.00	5.00	0.00	0.00	30.00	5.74	0.00	30.00	12.34	8.46	47.64	996.15	0.00	0.00	0.00
08.11.	19.0	2.29	0.00	5.00	0.00	0.00	30.00	6.76	0.00	30.00	6.27	8.31	46.76	996.21	0.00	0.00	0.00
09.11.	24.0	2.28	0.00	5.00	0.00	0.00	30.00	5.24	0.00	30.00	14.72	8.12	45.61	997.70	0.00	0.00	0.00
10.11.	21.0	2.25	0.00	5.00	0.00	0.00	30.00	2.45	0.00	30.00	12.28	8.20	46.63	998.40	0.00	0.00	0.00
11.11.	18.5	1.97	0.00	5.00	0.00	0.00	30.00	4.50	0.00	30.00	13.24	7.91	45.79	1004.97	0.00	0.00	0.00
12.11.	24.0	0.93	0.00	5.00	0.00	0.00	30.00	2.16	0.00	30.00	14.76	7.62	43.35	995.45	0.00	0.00	0.00
13.11.	19.0	1.27	0.00	5.00	0.00	0.00	30.00	1.35	0.00	30.00	15.22	6.80	41.55	990.04	0.00	0.00	0.00
14.11.	17.5	1.50	0.00	5.00	0.00	0.00	30.00	0.00	0.00	30.00	14.06	8.22	45.04	998.37	0.00	0.00	0.00
15.11.	22.5	1.30	0.00	5.00	0.00	0.00	30.00	0.15	0.00	30.00	14.74	6.66	42.81	1001.10	0.00	0.00	0.00
16.11.	20.0	0.97	0.00	5.00	0.00	0.00	30.00	0.00	0.00	30.00	13.89	7.04	42.67	1003.79	0.00	0.00	0.00
17.11.	18.0	1.55	0.00	5.00	0.00	0.00	30.00	0.16	0.00	30.00	12.85	6.81	41.50	1001.24	0.00	0.00	0.00
18.11.	24.0	1.82	0.00	5.00	0.00	0.00	30.00	0.57	0.00	30.00	11.52	7.99	44.18	1003.29	0.00	0.00	0.00
19.11.	17.5	2.46	0.20	5.00	0.00	0.00	30.00	2.05	0.27	30.00	9.66	8.20	44.64	1006.63	5.49	58905.39	1030.84
20.11.	24.0	1.68	0.33	5.00	0.00	0.00	30.00	9.66	1.92	30.00	13.80	5.32	45.70	1001.20	18.27	200426.27	4810.21
21.11.	22.0	3.06	0.59	5.00	0.00	0.00	30.00	18.86	3.78	30.00	8.28	8.04	44.21	1002.66	16.73	179058.84	3939.28
22.11.	6.0	0.20	0.03	5.00	0.00	0.00	30.00	0.00	0.00	30.00	9.39	5.00	34.92	1003.22	12.04	137769.70	826.61
23.11.	23.0	1.97	0.37	5.00	0.00	0.00	30.00	9.50	1.78	30.00	11.66	8.51	46.24	1004.98	17.77	188980.61	4346.59
24.11.	16.5	0.83	0.16	5.00	0.00	0.00	30.00	2.60	0.47	30.00	14.27	8.97	46.87	1002.26	17.30	181255.80	2990.72
25.11.	24.0	1.26	0.23	5.00	0.00	0.00	30.00	6.53	1.21	30.00	13.79	9.99	48.99	1000.91	17.90	185042.25	4441.02
26.11.	24.0	1.00	0.18	5.00	0.00	0.00	30.00	4.46	0.82	30.00	15.94	8.66	49.68	1001.75	17.46	182869.54	4388.83
27.11.	12.5	1.04	0.17	5.00	0.00	0.00	30.00	2.02	0.34	30.00	20.82	10.60	48.98	1000.11	16.09	164279.19	2053.47
28.11.	23.0	1.37	0.26	5.00	0.00	0.00	30.00	3.00	0.58	30.00	13.19	7.72	43.57	994.53	18.14	194075.88	4463.76
29.11.	24.0	2.56	0.49	5.00	0.62	0.11	30.00	3.15	0.61	30.00	13.38	8.72	45.86	997.10	18.36	193492.07	4643.81
30.11.	21.0	2.50	0.50	5.00	0.00	0.00	30.00	4.89	0.96	30.00	16.64	6.84	45.23	1007.42	18.18	198096.74	4160.04
MAV Average/ Sum	604.0	1.53	0.12	5.00	0.02	0.00	30.00	5.00	0.43	30.00	15.16	9.34	47.21	999.46	6.46	68854.21	42117.85
Availability in %		100.0 %	100.0 %	100.0 %	100.0 %	100.0 %	100.0 %	100.0 %	100.0 %	100.0 %	100.0 %	100.0 %	100.0 %	100.0 %	100.0 %	100.0 %	100.0 %
DAV Min (steady state)		0.04	0.00	5.00	0.00	0.00	30.00	0.00	0.00	30.00	6.27	5.00	34.92	988.67	0.00	0.00	0.00
Time		02.11.	01.11.	01.11.	01.11.	01.11.	01.11.	14.11.	01.11.	01.11.	08.11.	22.11.	22.11.	04.11.	01.11.	01.11.	01.11.
DAV Max (steady state)		3.06	0.59	5.00	0.62	0.11	30.00	18.86	3.78	30.00	25.07	19.33	63.26	1009.96	18.36	200426.27	4810.21
Time		21.11.	21.11.	01.11.	29.11.	29.11.	01.11.	21.11.	21.11.	01.11.	03.11.	03.11.	04.11.	01.11.	29.11.	20.11.	20.11.
Uncertainty mass (%)			233.3 %						607.0 %								

Operation Hours: 604.0, Steady Op Hours: 577.5, Availability O2: 100.0 %

Legend
 Letnje - 'S' ili; zimsko - 'W'
 status postrojenja: Stabilan rad - ' '; Zastoj - '-'; Pokretanje - 'SU'; Zaustavljanje - SD
 status merenja: Validno - ' '; Zamenska vrednost - 'S'; Održavanje - 'M'; Kvar - 'X'; Kalibracija - 'C'; Iznad validnog opsega kalibracije - 'P'; Greška - 'F'; Iznad opsega merenja - 'O'; Ispod opsega merenja - 'U'; Nema podataka - 'N'
 Usaglašenost sa GVE: >GVE - 'L'; >GVE+MN - 'I'; >GVE*1,2 - 'A'; >GVE*1,2+MN - 'a'; >2*GVE - 'B'; >2*GVE+MN - 'b'; Dnevna važeća srednja vrednost>GVE - 'T'; Dnevna važeća srednja vrednost>GVE+MN - 't'
 MN: HF=1 mg/m³; HCl=6 mg/m³; NH3=10 mg/m³
 Created on: 9.12.2019. 7:05:36, created according to ÖNORM M9412:2008 (EmiProtocol, V 6.0.1.0)