

| Day | Operation Hours | HF | | | O2 | Sadržaj vlage | T | P | Brzina | Protok | Kolic. Otp. gasa |
|--------------------------------|-----------------|--------------------|----------------|----------------|-----------------|-----------------|-----------------|-------------------|-----------------|---------------------|-------------------|
| | | mg/Nm ³ | kg/h | Limit | | | | | | | |
| 01.04. | 22.5 | 3.23 | 0.61 | 5.00 | 18.60 | 12.67 | 53.72 | 1008.73 | 19.09 | 189969.69 | 4274.33 |
| 02.04. | 23.0 | 1.95 | 0.38 | 5.00 | 18.07 | 11.06 | 50.79 | 1004.00 | 18.97 | 193196.47 | 4443.49 |
| 03.04. | 24.0 | 2.40 | 0.47 | 5.00 | 18.45 | 12.01 | 53.13 | 1001.71 | 19.55 | 195285.34 | 4686.83 |
| 04.04. | 24.0 | 0.63 | 0.12 | 5.00 | 18.67 | 11.93 | 53.13 | 1006.77 | 19.70 | 197982.50 | 4751.57 |
| 05.04. | 24.0 | 1.10 | 0.23 | 5.00 | 18.87 | 11.25 | 52.20 | 1012.40 | 20.38 | 208186.08 | 4996.45 |
| 06.04. | 5.5 | 2.14 | 0.44 | 5.00 | 18.36 | 9.57 | 47.61 | 1015.43 | 19.85 | 210344.91 | 1156.89 |
| 07.04. | 17.5 | 1.84 | 0.37 | 5.00 | 21.31 | 16.03 | 59.42 | 1020.24 | 21.61 | 206127.76 | 3607.25 |
| 08.04. | 24.0 | 0.47 | 0.09 | 5.00 | 21.16 | 19.95 | 63.38 | 1016.53 | 21.92 | 196044.74 | 4705.07 |
| 09.04. | 22.0 | 0.09 | 0.02 | 5.00 | 20.47 | 17.61 | 57.95 | 1010.16 | 21.36 | 198507.54 | 4367.17 |
| 10.04. | 15.0 | 0.00 | 0.00 | 5.00 | 19.51 | 7.77 | 43.58 | 1008.65 | 19.91 | 216189.22 | 3242.83 |
| 11.04. | 23.0 | 2.98 | 0.60 | 5.00 | 18.65 | 12.38 | 52.51 | 1010.57 | 19.95 | 200400.68 | 4609.23 |
| 12.04. | 24.0 | 3.98 | 0.78 | 5.00 | 18.37 | 13.07 | 54.08 | 1009.17 | 19.75 | 195709.40 | 4697.03 |
| 13.04. | 15.5 | 2.71 | 0.54 | 5.00 | 18.73 | 10.28 | 48.75 | 1001.38 | 19.45 | 200626.70 | 3109.71 |
| 14.04. | 24.0 | 4.35 | 0.96 | 5.00 | 17.64 | 8.77 | 46.92 | 1003.84 | 20.69 | 218996.53 | 5255.92 |
| 15.04. | 24.0 | 2.43 | 0.52 | 5.00 | 16.05 | 10.47 | 50.33 | 1013.07 | 20.61 | 213665.70 | 5127.98 |
| 16.04. | 12.0 | 2.09 | 0.41 | 5.00 | 18.46 | 9.95 | 47.95 | 1008.52 | 18.75 | 195808.83 | 2349.69 |
| 17.04. | 24.0 | 2.77 | 0.51 | 5.00 | 20.07 | 14.02 | 55.47 | 1003.59 | 18.85 | 182933.96 | 4390.42 |
| 18.04. | 24.0 | 3.70 | 0.67 | 5.00 | 19.62 | 14.91 | 56.22 | 1002.23 | 19.02 | 182072.89 | 4369.74 |
| 19.04. | 24.0 | 3.74 | 0.68 | 5.00 | 19.42 | 14.30 | 55.34 | 1000.39 | 18.91 | 182455.58 | 4378.96 |
| 20.04. | 20.5 | 3.73 | 0.67 | 5.00 | 21.38 | 14.33 | 55.80 | 1005.56 | 18.50 | 178979.85 | 3669.08 |
| 21.04. | 24.0 | 3.66 | 0.67 | 5.00 | 21.43 | 14.31 | 55.97 | 1005.81 | 18.84 | 182442.81 | 4378.66 |
| 22.04. | 21.0 | 3.41 | 0.61 | 5.00 | 21.44 | 14.30 | 55.99 | 1008.60 | 18.44 | 178609.28 | 3750.79 |
| 23.04. | 22.5 | 2.30 | 0.40 | 5.00 | 21.11 | 14.47 | 57.35 | 1007.52 | 17.94 | 172865.19 | 3889.45 |
| 24.04. | 10.5 | 2.34 | 0.41 | 5.00 | 20.92 | 10.36 | 47.95 | 1002.13 | 17.49 | 180499.76 | 1895.23 |
| 25.04. | 24.0 | 3.05 | 0.59 | 5.00 | 19.07 | 9.85 | 48.31 | 995.04 | 18.95 | 195389.50 | 4689.38 |
| 26.04. | 24.0 | 3.22 | 0.64 | 5.00 | 20.24 | 9.43 | 48.89 | 999.26 | 19.24 | 199941.65 | 4798.62 |
| 27.04. | 24.0 | 3.02 | 0.60 | 5.00 | 20.13 | 9.19 | 48.59 | 1000.94 | 19.20 | 200713.70 | 4817.12 |
| 28.04. | 24.0 | 2.47 | 0.42 | 5.00 | 19.53 | 7.39 | 42.68 | 998.24 | 15.58 | 167457.02 | 4018.97 |
| 29.04. | 24.0 | 2.97 | 0.62 | 5.00 | 19.05 | 9.74 | 48.38 | 996.28 | 20.13 | 208198.80 | 4996.78 |
| 30.04. | 24.0 | 3.21 | 0.65 | 5.00 | 18.57 | 10.37 | 49.84 | 997.91 | 19.89 | 203617.74 | 4886.84 |
| MAV Average/ Sum | 638.5 | 2.53 | 0.49 | 5.00 | 19.45 | 12.06 | 52.07 | 1005.82 | 19.42 | 195107.33 | 124311.48 |
| Availability in % | | 100.0 % | 100.0 % | 100.0 % | 100.0 % | 100.0 % | 100.0 % | 100.0 % | 100.0 % | 100.0 % | 100.0 % |
| DAV Min (steady state) Time | | 0.00 10.04. | 0.00 10.04. | 5.00 01.04. | 16.05 15.04. | 7.39 28.04. | 42.68 28.04. | 995.04 25.04. | 15.58 28.04. | 167457.02 28.04. | 1156.89 06.04. |
| DAV Max (steady state) Time | | 4.35 14.04. | 0.96 14.04. | 5.00 01.04. | 21.44 22.04. | 19.95 08.04. | 63.38 08.04. | 1020.24 07.04. | 21.92 08.04. | 218996.53 14.04. | 5255.92 14.04. |
| Uncertainty mass (%) | | | 57.1 % | | | | | | | | |

Operation Hours: 638.5, Steady Op Hours: 615.0, Availability O2: 100.0 %

Legend

Letnje - 'S' ili; zimsko - 'W'
 status postrojenja: Stabilan rad - ' '; Zastoj - '-'; Pokretanje - 'SU'; Zaustavljanje - SD
 status merenja: Validno - ' '; Zamenska vrednost - 'S'; Održavanje - 'M'; Kvar - 'X'; Kalibracija - 'C'; Iznad validnog opsega kalibracije - 'P'; Greška - 'F'; Iznad opsega merenja - 'O'; Ispod opsega merenja - 'U'; Nema podataka - 'N'
 Usaglašenost sa GVE: >GVE - 'L'; >GVE+MN - 'I'; >GVE*1,2 - 'A'; >GVE*1,2+MN - 'a'; >2*GVE - 'B'; >2*GVE+MN - 'b'; Dnevna važeća srednja vrednost>GVE - 'T'; Dnevna važeća srednja vrednost>GVE+MN - 't'

MN: HF=1 mg/m³; HCl=6 mg/m³; NH₃=10 mg/m³
 Created on: 1.3.2020, 7:13:22, created according to ÖNORM M9412:2008 (EmiProtocol, V 6.0.1.0)