

| Day                    | Operation Hours | HF                 |         |         | O2      | Sadržaj vlage | T       | P       | Brzina  | Protok    | Kolic. Otp. gasa |
|------------------------|-----------------|--------------------|---------|---------|---------|---------------|---------|---------|---------|-----------|------------------|
|                        |                 | mg/Nm <sup>3</sup> | kg/h    | Limit   |         |               |         |         |         |           |                  |
| 01.06.                 | 0.0             | ---                | N       | ---     | N       | ---           | N       | ---     | N       | ---       | N                |
| 02.06.                 | 0.0             | ---                | N       | ---     | N       | ---           | N       | ---     | N       | ---       | N                |
| 03.06.                 |                 |                    |         |         |         |               |         |         |         |           |                  |
| 04.06.                 |                 |                    |         |         |         |               |         |         |         |           |                  |
| 05.06.                 |                 |                    |         |         |         |               |         |         |         |           |                  |
| 06.06.                 |                 |                    |         |         |         |               |         |         |         |           |                  |
| 07.06.                 |                 |                    |         |         |         |               |         |         |         |           |                  |
| 08.06.                 | 7.0             | 0.04               | 0.01    | 5.00    | 19.98   | 8.38          | 47.02   | 997.70  | 19.54   | 206161.57 | 1443.13          |
| 09.06.                 | 19.0            | 0.26               | 0.06    | 5.00    | 20.06   | 8.86          | 46.77   | 998.02  | 20.35   | 213714.85 | 4060.54          |
| 10.06.                 | 24.0            | 0.41               | 0.09    | 5.00    | 20.10   | 9.84          | 49.11   | 997.83  | 20.76   | 214119.14 | 5138.85          |
| 11.06.                 | 23.5            | 0.77               | 0.17    | 5.00    | 19.92   | 7.87          | 46.54   | 997.87  | 20.52   | 217464.55 | 5110.40          |
| 12.06.                 | 24.0            | 0.18               | 0.04    | 5.00    | 20.23   | 7.50          | 51.98   | 997.35  | 20.52   | 215135.97 | 5163.30          |
| 13.06.                 | 24.0            | 0.05               | 0.01    | 5.00    | 20.60   | 8.22          | 51.27   | 997.21  | 20.45   | 213309.10 | 5119.43          |
| 14.06.                 | 22.5            | 2.91               | 0.62    | 5.00    | 20.51   | 8.52          | 48.90   | 995.63  | 20.36   | 212520.47 | 4781.71          |
| 15.06.                 | 24.0            | 3.78               | 0.77    | 5.00    | 21.07   | 11.45         | 52.10   | 997.97  | 20.28   | 203603.74 | 4886.52          |
| 16.06.                 | 14.0            | 2.09               | 0.40    | 5.00    | 20.69   | 7.85          | 43.70   | 998.04  | 17.26   | 183990.20 | 2575.86          |
| 17.06.                 | 22.5            | 1.75               | 0.37    | 5.00    | 20.78   | 8.43          | 45.74   | 996.66  | 19.81   | 209313.05 | 4709.59          |
| 18.06.                 | 21.5            | 1.01               | 0.21    | 5.00    | 20.64   | 6.93          | 41.28   | 997.78  | 19.28   | 210304.61 | 4521.55          |
| 19.06.                 | 23.5            | 1.58               | 0.33    | 5.00    | 20.73   | 8.24          | 45.21   | 1000.95 | 19.93   | 212548.60 | 4994.96          |
| 20.06.                 | 21.5            | 1.58               | 0.30    | 5.00    | 20.76   | 8.02          | 44.21   | 1001.79 | 15.66   | 165547.83 | 3559.28          |
| 21.06.                 | 20.5            | 1.87               | 0.39    | 5.00    | 20.73   | 8.15          | 44.42   | 1000.08 | 19.45   | 207777.89 | 4259.42          |
| 22.06.                 | 15.5            | 0.95               | 0.19    | 5.00    | 20.83   | 7.32          | 42.32   | 999.60  | 18.98   | 206104.02 | 3194.60          |
| 23.06.                 | 24.0            | 0.81               | 0.15    | 5.00    | 21.41   | 11.19         | 50.06   | 1003.00 | 17.08   | 171592.79 | 4118.21          |
| 24.06.                 | 22.5            | 0.71               | 0.13    | 5.00    | 21.59   | 12.65         | 53.51   | 1007.71 | 18.62   | 185328.89 | 4169.92          |
| 25.06.                 | 24.0            | 1.84               | 0.34    | 5.00    | 21.42   | 12.12         | 53.81   | 1008.23 | 18.77   | 188077.92 | 4513.89          |
| 26.06.                 | 24.0            | 1.76               | 0.41    | 5.00    | 21.64   | 13.19         | 55.11   | 1005.55 | 23.45   | 230225.46 | 5525.41          |
| 27.06.                 | 24.0            | 1.76               | 0.60    | 5.00    | 21.62   | 12.58         | 53.50   | 1003.34 | 35.04   | 348156.35 | 8355.74          |
| 28.06.                 | 24.0            | 1.45               | 0.49    | 5.00    | 21.70   | 13.47         | 55.91   | 1002.28 | 35.02   | 341581.02 | 8197.92          |
| 29.06.                 | 24.0            | 1.58               | 0.53    | 5.00    | 21.62   | 13.45         | 55.37   | 998.62  | 35.03   | 340898.98 | 8181.57          |
| 30.06.                 | 24.0            | 1.68               | 0.57    | 5.00    | 21.50   | 13.54         | 56.18   | 1002.57 | 35.01   | 340726.47 | 8177.45          |
| MAV Average/ Sum       | 497.5           | 1.34               | 0.31    | 5.00    | 20.88   | 9.90          | 49.31   | 1000.25 | 22.22   | 227747.98 | 114759.25        |
| Avalability in %       |                 | 100.0 %            | 100.0 % | 100.0 % | 100.0 % | 100.0 %       | 100.0 % | 100.0 % | 100.0 % | 100.0 %   | 100.0 %          |
| DAV Min (steady state) |                 | 0.04               | 0.01    | 5.00    | 19.92   | 6.93          | 41.28   | 995.63  | 15.66   | 165547.83 | 1443.13          |
| Time                   |                 | 08.06.             | 08.06.  | 08.06.  | 11.06.  | 18.06.        | 18.06.  | 14.06.  | 20.06.  | 20.06.    | 08.06.           |
| DAV Max (steady state) |                 | 3.78               | 0.77    | 5.00    | 21.70   | 13.54         | 56.18   | 1008.23 | 35.04   | 348156.35 | 8355.74          |
| Time                   |                 | 15.06.             | 15.06.  | 08.06.  | 28.06.  | 30.06.        | 30.06.  | 25.06.  | 27.06.  | 27.06.    | 27.06.           |
| Uncertainty mass (%)   |                 |                    | 90.3 %  |         |         |               |         |         |         |           |                  |

Operation Hours: 497.5, Steady Op Hours: 461.5, Availability O2: 100.0 %

Legend  
 Letnje - 'S' ili; zimsko - 'W'  
 status postrojenja: Stabilan rad - ' '; Zastoj - '-'; Pokretanje - 'SU'; Zaustavljanje - SD  
 status merenja: Validno - ' '; Zamenska vrednost - 'S'; Održavanje - 'M'; Kvar - 'X'; Kalibracija - 'C'; Iznad validnog opsega kalibracije - 'P'; Greška - 'F'; Iznad opsega merenja - 'O'; Ispod opsega merenja - 'U'; Nema podataka - 'N'  
 Usaglašenost sa GVE: >GVE - 'L'; >GVE+MN - 'I'; >GVE\*1,2 - 'A'; >GVE\*1,2+MN - 'a'; >2\*GVE - 'B'; >2\*GVE+MN - 'b'; Dnevna važeća srednja vrednost>GVE - 'T'; Dnevna važeća srednja vrednost>GVE+MN - 't'  
 MN: HF=1 mg/m<sup>3</sup>; HCl=6 mg/m<sup>3</sup>; NH3=10 mg/m<sup>3</sup>  
 Created on: 17.2020, 16:52:24, created according to ÖNORM M9412:2008 (EmiProtocol, V 6.0.1.0)