

Day	Operation Hours	HF			O2	Sadržaj vlage	T	P	Brzina	Protok	Kolic. Otp. gasa	
		mg/Nm ³	kg/h	Limit								
01.10.	20.5	5.28	1.08	5.00	22.23	13.72	49.25	995.13	20.47	201753.69	4135.94	
02.10.	24.0	3.00	0.63	5.00	22.13	13.71	50.41	995.17	21.26	208875.63	5013.02	
03.10.	23.0	1.95	0.41	5.00	21.86	11.49	47.67	993.73	20.96	212587.15	4889.52	
04.10.	21.0	0.85	0.18	5.00	22.10	13.26	46.38	995.22	20.64	205620.20	4318.02	
05.10.	23.0	0.02	0.00	5.00	22.62	17.85	52.26	997.34	21.12	196719.82	4524.56	
06.10.	11.5	0.81	0.17	5.00	21.77	12.36	44.72	1000.45	18.50	186964.07	2150.09	
07.10.	24.0	3.72	0.81	5.00	21.71	11.69	46.34	998.90	21.22	216932.57	5206.41	
08.10.	24.0	2.57	0.56	5.00	21.55	10.34	46.97	1005.54	21.03	219268.14	5262.43	
09.10.	24.0	1.78	0.39	5.00	21.57	10.39	47.53	1009.83	20.76	216813.04	5203.49	
10.10.	20.5	0.44	0.10	5.00	21.30	8.82	39.64	1005.46	20.92	227049.58	4654.51	
11.10.	24.0	0.00	0.00	5.00	21.05	7.53	39.54	1001.63	20.29	222383.89	5337.22	
12.10.	6.5	0.00	0.00	5.00	21.03	6.69	36.94	996.58	18.09	200220.14	1301.44	
13.10.	20.0	2.30	0.48	5.00	21.47	9.91	44.91	994.28	20.14	209936.65	4198.74	
14.10.	24.0	2.69	0.56	5.00	21.30	8.99	44.68	998.77	19.67	208125.40	4995.01	
15.10.	22.0	2.67	0.54	5.00	21.27	9.34	44.62	997.76	19.34	203652.51	4480.35	
16.10.	19.0	3.70	0.74	5.00	21.47	10.52	45.32	999.50	19.00	196724.43	3737.78	
17.10.	21.5	2.69	0.55	5.00	21.89	12.85	44.58	1003.20	19.37	197253.19	4240.99	
18.10.	24.0	0.94	0.17	5.00	22.92	19.70	51.95	1009.25	19.58	180321.30	4327.70	
19.10.	19.0	2.70	0.47	5.00	22.93	19.73	52.35	1013.36	19.04	175791.20	3340.01	
20.10.	10.5	3.13	0.55	5.00	22.93	19.87	52.59	1013.30	19.19	177033.22	1858.87	
21.10.	14.0	4.54	0.80	5.00	22.85	18.48	49.30	1010.34	18.88	178027.66	2492.38	
22.10.	24.0	3.06	0.58	5.00	21.76	12.93	48.72	1009.31	18.73	188929.10	4534.30	
23.10.	20.5	3.11	0.58	5.00	21.71	12.61	50.43	1006.60	18.70	187760.06	3849.07	
24.10.	23.5	3.46	0.64	5.00	21.69	12.57	50.79	1004.17	18.68	186998.07	4394.47	
25.10.	19.5	2.72	0.51	5.00	21.45	11.59	49.52	1001.25	18.39	185618.53	3619.58	
26.10.	24.0	2.48	0.48	5.00	21.35	11.56	50.88	999.79	19.09	192319.13	4615.63	
27.10.	24.0	2.65	0.51	5.00	21.42	11.89	50.45	999.29	18.96	190756.23	4578.16	
28.10.	5.5	1.36	0.25	5.00	20.82	10.95	43.63	1001.60	17.88	185836.19	1022.09	
29.10.	0.0	--- N	--- N	--- N	--- N	--- N	--- N	--- N	--- N	--- N	--- N	
30.10.	0.0	--- N	--- N	--- N	--- N	--- N	--- N	--- N	--- N	--- N	--- N	
31.10.	0.0	--- N	--- N	--- N	--- N	--- N	--- N	--- N	--- N	--- N	--- N	
MAV Average/ Sum	561.0	2.31	0.46	5.00	21.79	12.55	47.23	1002.03	19.64	198581.10	112281.78	
Avalability in %		100.0 %	100.0 %	100.0 %	100.0 %	100.0 %	100.0 %	100.0 %	100.0 %	100.0 %	100.0 %	
DAV Min (steady state)		0.00	0.00	5.00	20.82	6.69	36.94	993.73	17.88	175791.20	1022.09	
Time		11.10.	05.10.	01.10.	28.10.	12.10.	12.10.	03.10.	28.10.	19.10.	28.10.	
DAV Max (steady state)		5.28	1.08	5.00	22.93	19.87	52.59	1013.36	21.26	227049.58	5337.22	
Time		01.10.	01.10.	01.10.	19.10.	20.10.	20.10.	19.10.	02.10.	10.10.	11.10.	
Uncertainty mass (%)			60.9 %									

Operation Hours: 561.0, Steady Op Hours: 527.0, Availability O2: 100.0 %

Legend
 Letnje - 'S' ili; zimsko - 'W'
 status postrojenja: Stabilan rad - ' '; Zastoj - 'L'; Pokretanje - 'SU'; Zaustavljanje - 'SD'
 status merenja: Validno - 'V'; Zamenska vrednost - 'S'; Održavanje - 'M'; Kvar - 'X'; Kalibracija - 'C'; Iznad validnog opsega kalibracije - 'P'; Greška - 'F'; Iznad opsega merenja - 'O'; Ispod opsega merenja - 'U'; Nema podataka - 'N'
 Usaglašenost sa GVE: >GVE - 'L'; >GVE+MN - 'I'; >GVE*1,2 - 'A'; >GVE*1,2+MN - 'a'; >2*GVE - 'B'; >2*GVE+MN - 'b'; Dnevna važeća srednja vrednost>GVE - 'T'; Dnevna važeća srednja vrednost>GVE+MN - 't'
 MN: HF= 1 mg/m³; HCl=6 mg/m³; NH3=10 mg/m³
 Created on: 21.10.2020, 7:01:42, created according to ÖNORM M9412:2008 (EmiProtocol, V 6.0.1.0)