

| Day | Operation Hours | HF | | | O2 | Sadržaj vlage | T | P | Brzina | Protok | Kolic. Otp. gasa |
|------------------------|-----------------|--------------------|---------|---------|---------|---------------|---------|---------|---------|-----------|------------------|
| | | mg/Nm ³ | kg/h | Limit | | | | | | | |
| 01.12. | 24.0 | 3.03 | 0.58 | 5.00 | 21.19 | 9.98 | 44.56 | 1009.22 | 18.27 | 193223.83 | 4637.36 |
| 02.12. | 24.0 | 2.91 | 0.55 | 5.00 | 21.20 | 9.91 | 44.66 | 1007.15 | 18.02 | 190243.26 | 4565.81 |
| 03.12. | 16.0 | 2.08 | 0.40 | 5.00 | 21.15 | 9.40 | 43.21 | 998.57 | 18.56 | 196160.30 | 3138.53 |
| 04.12. | 24.0 | 2.07 | 0.41 | 5.00 | 21.18 | 9.87 | 43.23 | 994.90 | 19.01 | 199127.02 | 4779.06 |
| 05.12. | 24.0 | 1.86 | 0.36 | 5.00 | 21.22 | 10.53 | 43.44 | 998.44 | 18.69 | 194958.82 | 4679.01 |
| 06.12. | 24.0 | 1.94 | 0.37 | 5.00 | 21.21 | 10.50 | 43.27 | 997.38 | 18.44 | 192405.41 | 4617.76 |
| 07.12. | 17.0 | 1.88 | 0.37 | 5.00 | 21.20 | 10.48 | 41.91 | 995.20 | 18.93 | 197988.40 | 3365.83 |
| 08.12. | 19.0 | 2.22 | 0.43 | 5.00 | 21.14 | 9.64 | 41.51 | 997.76 | 17.64 | 186183.16 | 3537.50 |
| 09.12. | 23.0 | 2.79 | 0.53 | 5.00 | 21.19 | 9.93 | 43.47 | 993.86 | 18.21 | 190517.57 | 4381.90 |
| 10.12. | 22.0 | 2.69 | 0.55 | 5.00 | 21.17 | 9.38 | 43.18 | 995.62 | 19.52 | 206001.98 | 4532.06 |
| 11.12. | 24.0 | 3.23 | 0.66 | 5.00 | 21.17 | 8.81 | 43.38 | 995.78 | 19.21 | 203944.40 | 4894.64 |
| 12.12. | 24.0 | 3.22 | 0.64 | 5.00 | 21.18 | 8.66 | 44.23 | 991.69 | 18.80 | 198524.95 | 4764.61 |
| 13.12. | 18.5 | 2.85 | 0.57 | 5.00 | 21.13 | 8.17 | 43.60 | 997.71 | 18.60 | 199071.28 | 3682.81 |
| 14.12. | 0.0 | --- | N | --- | N | --- | N | --- | N | --- | N |
| 15.12. | 0.0 | --- | N | --- | N | --- | N | --- | N | --- | N |
| 16.12. | 0.0 | --- | N | --- | N | --- | N | --- | N | --- | N |
| 17.12. | 21.0 | 0.49 | 0.08 | 5.00 | 22.39 | 17.24 | 52.41 | 1014.30 | 19.19 | 183312.22 | 3849.56 |
| 18.12. | 24.0 | 1.17 | 0.22 | 5.00 | 22.40 | 18.68 | 59.30 | 1017.00 | 20.12 | 185296.66 | 4447.14 |
| 19.12. | 24.0 | 2.82 | 0.52 | 5.00 | 22.37 | 18.39 | 60.08 | 1016.14 | 20.14 | 185446.58 | 4450.70 |
| 20.12. | 22.5 | 2.13 | 0.39 | 5.00 | 21.95 | 15.96 | 56.72 | 1014.31 | 19.81 | 189578.82 | 4265.52 |
| 21.12. | 24.0 | 2.97 | 0.54 | 5.00 | 22.38 | 18.78 | 61.86 | 1014.61 | 19.96 | 181710.20 | 4361.06 |
| 22.12. | 19.0 | 1.60 | 0.29 | 5.00 | 20.94 | 9.68 | 53.14 | 1012.19 | 18.05 | 186744.72 | 3548.14 |
| 23.12. | 13.0 | 2.05 | 0.42 | 5.00 | 20.35 | 5.31 | 44.23 | 1008.83 | 18.60 | 207368.90 | 2695.80 |
| 24.12. | 21.5 | 2.15 | 0.46 | 5.00 | 20.49 | 6.23 | 44.23 | 1002.24 | 19.68 | 215490.08 | 4633.02 |
| 25.12. | 24.0 | 2.38 | 0.50 | 5.00 | 20.44 | 5.97 | 45.38 | 998.77 | 19.42 | 211955.75 | 5086.93 |
| 26.12. | 24.0 | 1.93 | 0.41 | 5.00 | 20.55 | 6.08 | 45.29 | 1005.87 | 19.68 | 216224.32 | 5189.36 |
| 27.12. | 24.0 | 1.73 | 0.38 | 5.00 | 20.43 | 4.58 | 42.43 | 999.76 | 19.70 | 220424.31 | 5290.21 |
| 28.12. | 24.0 | 1.49 | 0.30 | 5.00 | 20.66 | 5.67 | 42.28 | 986.36 | 18.47 | 201567.16 | 4837.61 |
| 29.12. | 21.5 | 1.21 | 0.23 | 5.00 | 20.68 | 5.73 | 41.62 | 990.29 | 17.35 | 189645.73 | 4077.35 |
| 30.12. | 23.5 | 0.81 | 0.16 | 5.00 | 20.72 | 5.89 | 41.47 | 993.48 | 18.01 | 197984.77 | 4652.66 |
| 31.12. | 23.0 | 0.76 | 0.16 | 5.00 | 20.82 | 6.53 | 43.13 | 995.69 | 18.65 | 203041.46 | 4669.94 |
| MAV Average/ Sum | 616.5 | 2.09 | 0.41 | 5.00 | 21.18 | 9.86 | 46.33 | 1001.54 | 18.88 | 197290.79 | 121631.88 |
| Avalability in % | | 100.0 % | 100.0 % | 100.0 % | 100.0 % | 100.0 % | 100.0 % | 100.0 % | 100.0 % | 100.0 % | 100.0 % |
| DAV Min (steady state) | | 0.49 | 0.08 | 5.00 | 20.35 | 4.58 | 41.47 | 986.36 | 17.35 | 181710.20 | 2695.80 |
| Time | | 17.12. | 17.12. | 01.12. | 23.12. | 27.12. | 30.12. | 28.12. | 29.12. | 21.12. | 23.12. |
| DAV Max (steady state) | | 3.23 | 0.66 | 5.00 | 22.40 | 18.78 | 61.86 | 1017.00 | 20.14 | 220424.31 | 5290.21 |
| Time | | 11.12. | 11.12. | 01.12. | 18.12. | 21.12. | 21.12. | 18.12. | 19.12. | 27.12. | 27.12. |
| Uncertainty mass (%) | | | 68.3 % | | | | | | | | |

Operation Hours: 616.5, Steady Op Hours: 589.5, Availability O2: 100.0 %

Legend
 Letnje - 'S' ili; zimsko - 'W'
 status postrojenja: Stabilan rad - ' '; Zastoj - 'L'; Pokretanje - 'SU'; Zaustavljanje - SD
 status merenja: Validno - 'V'; Zamenska vrednost - 'S'; Održavanje - 'M'; Kvar - 'X'; Kalibracija - 'C'; Iznad validnog opsega kalibracije - 'P'; Greška - 'F'; Iznad opsega merenja - 'O'; Ispod opsega merenja - 'U'; Nema podataka - 'N'
 Usaglašenost sa GVE: >GVE - 'L'; >GVE+MN - 'I'; >GVE*1,2 - 'A'; >GVE*1,2+MN - 'a'; >2*GVE - 'B'; >2*GVE+MN - 'b'; Dnevna važeća srednja vrednost>GVE - 'T'; Dnevna važeća srednja vrednost>GVE+MN - 'I'
 MN: HF=1 mg/m³; HCl=6 mg/m³; NH3=10 mg/m³
 Created on: 11.12.2021 19:52, created according to ÖNORM M9412:2008 (EmiProtocol, V 6.0.1.0)