

Day	Operation Hours	HF			O2	Sadržaj vlage	T	P	Brzina	Protok	Kolic. Otp. gasa	
		mg/Nm ³	kg/h	Limit								
01.07.	0,0	---	---	---	---	---	---	---	---	---	---	---
02.07.	0,0	---	---	---	---	---	---	---	---	---	---	---
03.07.	0,0	---	---	---	---	---	---	---	---	---	---	---
04.07.	0,0	---	---	---	---	---	---	---	---	---	---	---
05.07.	0,0	---	---	---	---	---	---	---	---	---	---	---
06.07.	0,0	---	---	---	---	---	---	---	---	---	---	---
07.07.	0,0	---	---	---	---	---	---	---	---	---	---	---
08.07.	0,0	---	---	---	---	---	---	---	---	---	---	---
09.07.	0,0	---	---	---	---	---	---	---	---	---	---	---
10.07.	0,0	---	---	---	---	---	---	---	---	---	---	---
11.07.	0,0	---	---	---	---	---	---	---	---	---	---	---
12.07.	0,0	---	---	---	---	---	---	---	---	---	---	---
13.07.	0,0	---	---	---	---	---	---	---	---	---	---	---
14.07.	0,0	---	---	---	---	---	---	---	---	---	---	---
15.07.	0,0	---	---	---	---	---	---	---	---	---	---	---
16.07.	0,0	---	---	---	---	---	---	---	---	---	---	---
17.07.	0,0	---	---	---	---	---	---	---	---	---	---	---
18.07.	0,0	---	---	---	---	---	---	---	---	---	---	---
19.07.	0,0	---	---	---	---	---	---	---	---	---	---	---
20.07.	0,0	---	---	---	---	---	---	---	---	---	---	---
21.07.	0,0	---	---	---	---	---	---	---	---	---	---	---
22.07.	0,0	---	---	---	---	---	---	---	---	---	---	---
23.07.	4,5	1,78	0,40	5,00	19,39	6,64	38,01	1001,12	19,82	219851,74	989,34	
24.07.	24,0	2,32	0,55	5,00	19,36	9,95	46,69	1000,28	22,66	236239,29	5669,74	
25.07.	19,0	1,12	0,27	5,00	20,12	8,45	43,02	998,25	22,34	238966,83	4540,34	
26.07.	18,5	2,61	0,61	5,00	20,17	9,52	45,35	999,82	21,44	224896,48	4160,62	
27.07.	21,5	1,17	0,27	5,00	20,33	8,22	42,40	1001,84	20,98	225893,78	4856,75	
28.07.	23,0	0,59	0,11	5,00	20,96	8,55	43,18	999,59	18,09	192748,28	4433,24	
29.07.	24,0	0,15	0,03	5,00	20,86	11,05	48,89	999,31	20,83	212904,95	5109,72	
30.07.	24,0	1,31	0,28	5,00	21,52	10,64	48,24	997,50	20,82	213739,92	5129,74	
31.07.	24,0	1,07	0,23	5,00	21,80	10,38	47,68	995,76	20,90	215278,72	5166,68	
MAV Average/ Sum	182,5	1,35	0,31	5,00	20,50	9,27	44,83	999,27	20,88	220057,78	40056,17	
Availability in %		100,0 %	100,0 %	100,0 %	100,0 %	100,0 %	100,0 %	100,0 %	100,0 %	100,0 %	100,0 %	
DAV Min (steady state)		0,15	0,03	5,00	19,36	6,64	38,01	995,76	18,09	192748,28	989,34	
Time		29,07.	29,07.	23,07.	24,07.	23,07.	23,07.	31,07.	28,07.	28,07.	23,07.	
DAV Max (steady state)		2,61	0,61	5,00	21,80	11,05	48,89	1001,84	22,66	238966,83	5669,74	
Time		26,07.	26,07.	23,07.	31,07.	29,07.	29,07.	27,07.	24,07.	25,07.	24,07.	
Uncertainty mass (%)			90,3 %									

Operation Hours: 182.5, Steady Op Hours: 167.0, Availability O2: 100.0 %

Legend
 Letnje - 'S' ili zimsko - 'W'
 status postrojenja: Stabilan rad - ' '; Zastoj - '-'; Pokretanje - 'SU'; Zaustavljanje - 'SD'
 status merenja: Validno - 'V'; Zamenska vrednost - 'S'; Održavanje - 'M'; Kvar - 'X'; Kalibracija - 'C'; Iznad validnog opsega kalibracije - 'P'; Greška - 'F'; Iznad opsega merenja - 'O'; Ispod opsega merenja - 'U'; Nema podataka - 'N'
 Usaglasenost sa GVE: >GVE - 'L'; >GVE+MN - 'I'; >GVE*1,2 - 'A'; >GVE*1,2+MN - 'b'; >2*GVE - 'B'; >2*GVE+MN - 'b'; Dnevna vazeća srednja vrednost>GVE - 'T'; Dnevna vazeća srednja vrednost>GVE+MN - 'I'
 MN: HF= 1 mg/m³; HCl=6 mg/m³; NH3=10 mg/m³