

Day	Operation Hours	HF			O2	Sadržaj vlage	T	P	Brzina	Protok	Kolic. Otp. gasa
		mg/Nm <sup>3</sup>	kg/h	Limit							
01.08.	24.0	2.91	0.58	5.00	23.20	12.92	56.41	1000.52	19.43	202447.91	4858.72
02.08.	23.0	0.89	0.15	5.00	23.11	10.89	48.24	1001.60	14.92	158642.96	3648.75
03.08.	20.5	1.57	0.32	5.00	23.43	12.36	50.94	1002.28	19.23	205327.93	4209.20
04.08.	24.0	1.01	0.21	5.00	23.36	13.55	55.59	1002.07	19.84	206074.18	4945.78
05.08.	24.0	0.66	0.13	5.00	23.24	13.76	52.86	1000.16	19.39	202261.46	4854.32
06.08.	24.0	0.56	0.11	5.00	22.82	16.00	56.70	998.72	19.11	191599.87	4598.40
07.08.	24.0	0.41	0.07	5.00	23.11	13.73	57.32	1001.79	18.17	187272.92	4494.54
08.08.	19.0	0.58	0.09	5.00	23.45	11.33	43.38	1002.33	13.90	148876.37	2828.67
09.08.	23.0	0.65	0.13	5.00	24.05	12.04	56.18	1005.86	19.54	207270.80	4767.23
10.08.	19.0	0.30	0.06	5.00	23.91	5.89	44.54	1005.49	18.22	213520.68	4056.91
11.08.	23.5	0.19	0.04	5.00	24.14	5.51	48.88	1004.01	18.11	210208.70	4939.89
12.08.	24.0	0.30	0.07	5.00	23.46	6.04	52.40	1001.39	18.98	216164.94	5187.96
13.08.	24.0	0.77	0.13	5.00	22.09	20.70	51.97	998.75	17.91	172016.96	4128.41
14.08.	24.0	0.16	0.03	5.00	22.54	9.12	53.00	996.22	19.11	209050.28	5017.23
15.08.	16.0	0.27	0.05	5.00	22.48	8.05	44.56	993.40	15.59	173940.81	2783.06
16.08.	24.0	1.07	0.18	5.00	21.27	21.66	54.70	995.92	18.01	169145.01	4059.45
17.08.	24.0	1.42	0.27	5.00	21.66	16.19	55.04	998.05	18.61	186847.09	4484.35
18.08.	24.0	1.19	0.23	5.00	22.03	11.73	56.48	997.76	18.52	195052.53	4681.25
19.08.	21.5	0.75	0.13	5.00	21.95	7.42	41.91	995.51	12.91	145342.53	3124.85
20.08.	24.0	0.23	0.05	5.00	21.93	9.62	44.03	996.15	18.01	201579.62	4637.93
21.08.	19.5	0.23	0.04	5.00	22.28	10.16	41.43	995.53	17.62	197373.11	3848.79
22.08.	21.5	0.19	0.04	5.00	21.80	12.48	46.97	995.38	18.05	193252.09	4154.93
23.08.	20.5	0.17	0.03	5.00	22.28	12.65	44.27	999.28	17.58	190378.10	3902.75
24.08.	24.0	0.36	0.07	5.00	22.82	8.81	43.88	1001.75	15.91	181161.59	4347.89
25.08.	24.0	0.61	0.12	5.00	22.16	11.36	49.88	1000.88	18.46	198921.39	4798.15
26.08.	14.0	0.22	0.04	5.00	22.57	8.73	41.15	997.18	15.91	180807.45	2531.32
27.08.	24.0	0.11	0.02	5.00	22.58	9.33	44.35	996.61	18.63	208972.47	5015.36
28.08.	20.5	0.15	0.03	5.00	22.67	9.35	42.91	998.20	17.99	202710.81	4155.56
29.08.	22.5	0.11	0.02	5.00	22.49	11.32	45.64	659.22	18.65	204983.71	4612.14
30.08.	23.0	0.12	0.03	5.00	22.58	10.30	42.98	27.39	18.28	204741.99	4709.06
31.08.	24.0	0.33	0.06	5.00	22.17	11.34	47.56	0.00	18.10	197147.10	4731.54
MAV Average/ Sum	691.0	0.60	0.11	5.00	22.70	11.43	48.90	924.81	17.83	192390.11	133314.39
Availability in %		100.0 %	100.0 %	100.0 %	100.0 %	100.0 %	100.0 %	100.0 %	100.0 %	100.0 %	100.0 %
DAV Min (steady state)		0.11	0.02	5.00	21.27	5.51	41.15	0.00	12.91	145342.53	2531.32
Time		27.08.	27.08.	01.08.	16.08.	11.08.	26.08.	31.08.	19.08.		26.08.
DAV Max (steady state)		2.91	0.58	5.00	24.14	21.66	57.32	1005.86	19.84	216164.94	5187.96
Time		01.08.	01.08.	01.08.	11.08.	16.08.	07.08.	09.08.	04.08.	12.08.	12.08.
Uncertainty mass (%)			254.6 %								

Operation Hours: 691.0, Steady Op Hours: 628.5, Availability O2: 100.0 %

Legend  
 Letrije - 'S' ili: zimsko - 'W'  
 status postrojenja: Stabilan rad - '1'; Zastoj - '-'; Pokretanje - 'SU'; Zaustavljanje - 'SD'  
 status merjenja: Validno - '1'; Zamenska vrednost - 'S'; Održavanje - 'M'; Kvar - 'X'; Kalibracija - 'C'; Iznad validnog opsega kalibracije - 'P'; Greška - 'F'; Iznad opsega merjenja - 'O'; Ispod opsega merjenja - 'U'; Nema podataka - 'N'  
 Usaglasenost sa GVE: >GVE - 'L'; >GVE+MN - 'I'; >GVE\*1.2 - 'A'; >GVE\*1.2+MN - 'a'; >2\*GVE - 'B'; >2\*GVE+MN - 'b'; Dnevna važeća srednja vrednost>GVE - 'T'; Dnevna važeća srednja vrednost>GVE+MN - 't'  
 MN: HF= 1 mg/m<sup>3</sup>; HCl=6 mg/m<sup>3</sup>; NH3=10 mg/m<sup>3</sup>

Created on/ at 1.9.2022./ 00:02, created according to ČNORM M9412:2008 (EmiProtocol Version V 6.5, Parameter Version V1)