

Day	Operation Hours	HF			O2	Sadržaj vlage	T	P	Brzina	Protok	Kolic. Otp. gasa
		mg/Nm ³	kg/h	Limit							
01.01.	15.5	0.89	0.18	5.00	23.22	9.99	43.22	0.00	18.32	208579.88	3232.99
02.01.	19.0	0.88	0.18	5.00	23.29	7.42	42.38	0.00	18.33	214913.95	4083.36
03.01.	20.0	2.14	0.42	5.00	23.07	16.90	43.72	0.00	18.66	195699.67	3913.97
04.01.	24.0	1.78	0.34	5.00	23.43	17.26	45.20	0.00	18.77	195344.41	4688.27
05.01.	21.5	0.92	0.18	5.00	23.17	16.52	45.86	0.00	19.04	197727.13	4251.18
06.01.	19.0	0.77	0.15	5.00	23.18	14.44	46.23	0.00	18.51	197192.57	3746.63
07.01.	6.5	1.07	0.18	5.00	23.25	20.82	40.60	0.00	17.24	172910.62	1123.92
08.01.	0.0	---N	---N	---N	---N	---N	---N	---N	---N	---N	---N
09.01.	7.5	0.66	0.12	5.00	22.96	23.21	45.91	0.00	19.65	184049.81	1380.34
10.01.	24.0	0.62	0.11	5.00	22.72	19.73	46.14	0.00	19.49	192193.45	4612.65
11.01.	11.5	1.32	0.27	5.00	23.18	15.24	42.70	0.00	20.56	217603.58	2502.42
12.01.	2.5	1.24	0.23	5.00	23.14	20.76	46.96	0.00	18.75	184327.90	460.82
13.01.	2.0	0.15	0.03	5.00	22.97	11.47	37.59	0.00	19.36	218872.47	437.75
14.01.	19.0	0.64	0.12	5.00	21.94	19.28	46.92	0.00	19.24	192920.63	3665.51
15.01.	23.5	1.44	0.25	5.00	21.71	21.02	47.54	0.00	17.85	173692.94	4081.77
16.01.	16.5	1.95	0.35	5.00	21.72	19.44	46.55	0.00	18.33	180366.93	2976.06
17.01.	16.5	1.38	0.28	5.00	22.50	12.00	41.05	0.00	19.38	210316.11	3470.21
18.01.	13.0	0.48	0.09	5.00	22.37	15.25	42.40	0.00	18.17	186248.41	2447.22
19.01.	24.0	0.40	0.07	5.00	22.22	17.70	44.66	0.00	18.40	185860.42	4460.64
20.01.	24.0	0.27	0.05	5.00	22.17	18.03	43.98	0.00	18.36	186283.64	4470.84
21.01.	24.0	1.24	0.21	5.00	22.00	18.67	46.87	0.00	17.73	175402.39	4209.64
22.01.	23.5	1.39	0.27	5.00	21.90	18.43	46.36	0.00	19.16	193864.05	4555.82
23.01.	24.0	1.40	0.26	5.00	22.33	12.94	44.33	0.00	18.03	196411.04	4713.88
24.01.	17.5	2.31	0.43	5.00	22.50	15.95	43.59	0.00	17.95	190674.98	3356.80
25.01.	15.0	0.52	0.10	5.00	22.49	17.11	48.84	0.00	19.08	196387.83	2945.82
26.01.	23.0	0.33	0.06	5.00	22.91	22.33	52.38	0.00	19.14	180820.84	4158.89
27.01.	24.0	0.73	0.13	5.00	23.08	23.80	54.31	0.00	19.06	174989.91	4199.73
28.01.	22.5	0.94	0.16	5.00	23.03	16.20	53.07	0.00	18.69	190565.25	4287.70
29.01.	21.0	0.31	0.05	5.00	22.76	16.27	48.33	0.00	17.98	186561.47	3917.81
30.01.	19.5	0.28	0.05	5.00	22.55	21.30	50.95	0.00	17.54	168766.51	3290.94
31.01.	16.0	0.21	0.04	5.00	22.60	14.54	39.54	0.00	18.46	200237.23	3203.78
MAV Average/ Sum	539.5	0.96	0.18	5.00	22.68	17.17	45.60	0.00	18.64	191726.20	102827.36
Availability in %		100.0 %	100.0 %	100.0 %	100.0 %	100.0 %	100.0 %	100.0 %	100.0 %	100.0 %	100.0 %
DAV Min (steady state)		0.15	0.03	5.00	21.71	7.42	37.59	0.00	17.24	168766.51	437.75
Time		13.01.	13.01.	01.01.	15.01.	02.01.	13.01.	01.01.	07.01.	30.01.	13.01.
DAV Max (steady state)		2.31	0.43	5.00	23.43	23.80	54.31	0.00	20.56	218872.47	4713.88
Time		24.01.	24.01.	01.01.	04.01.	27.01.	27.01.	01.01.	11.01.	13.01.	23.01.
Uncertainty mass (%)			155.6 %								

Operation Hours: 539.5, Steady Op Hours: 508.0, Availability O2: 100.0 %

Legend
 Letnje - 'S' ili; zimsko - 'W'
 status postrojenja: Stabilan rad - '1'; Zastoj - '-'; Pokretanje - 'SU'; Zaustavljanje - 'SD'
 status merenja: Validno - '1'; Zamenska vrednost - 'M'; Odrzavanje - 'M'; Kvar - 'X'; Kalibracija - 'C'; Iznad validnog opsega kalibracije - 'P'; Greška - 'F'; Iznad opsega merenja - 'O'; Ispod opsega merenja - 'U'; Nema podataka - 'N'
 Usaglasenost sa GVE: >GVE - 'L'; >GVE+MN - 'I'; >GVE*1.2 - 'A'; >GVE*1.2+MN - 'a'; >2*GVE - 'B'; >2*GVE+MN - 'b'; Dnevna vazeca srednja vrednost>GVE - 'T'; Dnevna vazeca srednja vrednost>GVE+MN - 't'
 MN: HF= 1 mg/m³; HCl=6 mg/m³; NH3=10 mg/m³