

Day	Operation Hours	HF			O2	Sadržaj vlage	T	P	Brzina	Protok	Kolic. Otp. gasa
		mg/Nm <sup>3</sup>	kg/h	Limit							
01.02.	24.0	0.17	0.03	5.00	22.51	12.06	40.83	0.00	18.33	203564.64	4895.56
02.02.	24.0	0.20	0.04	5.00	22.59	10.10	40.99	0.00	18.25	207025.58	4968.63
03.02.	11.5	0.14	0.03	5.00	22.62	9.15	37.42	0.00	18.27	212446.89	2443.13
04.02.	22.0	0.13	0.03	5.00	22.60	8.03	37.45	0.00	18.56	217893.65	4793.65
05.02.	19.5	0.16	0.03	5.00	22.71	11.23	44.68	0.00	18.36	205863.02	4014.33
06.02.	24.0	0.18	0.04	5.00	22.54	12.18	46.99	0.00	18.25	201618.73	4838.86
07.02.	24.0	0.35	0.07	5.00	22.24	13.45	48.41	0.00	19.41	210980.25	5063.55
08.02.	24.0	0.39	0.08	5.00	22.43	12.91	48.69	0.00	19.42	212608.81	5102.64
09.02.	24.0	0.33	0.07	5.00	22.73	12.51	47.50	0.00	19.10	210560.36	5053.47
10.02.	24.0	0.25	0.05	5.00	22.68	12.04	48.43	0.00	19.42	214531.22	5148.73
11.02.	24.0	0.25	0.05	5.00	22.47	13.95	49.50	0.00	19.65	211046.37	5065.11
12.02.	24.0	0.31	0.06	5.00	22.44	14.66	51.41	0.00	19.56	206779.35	4962.73
13.02.	24.0	0.29	0.06	5.00	22.67	13.61	49.91	0.00	19.45	208979.38	5037.07
14.02.	7.5	0.30	0.06	5.00	22.45	14.36	50.46	0.00	19.70	208995.48	1574.22
15.02.	0.0	----N	----N	----N	----N	----N	----N	----N	----N	----N	----N
16.02.	0.0	----N	----N	----N	----N	----N	----N	----N	----N	----N	----N
17.02.	15.5	0.22	0.04	5.00	22.41	11.91	48.18	0.00	18.23	199371.13	3090.23
18.02.	24.0	0.19	0.04	5.00	22.41	12.92	49.12	0.00	18.46	198161.14	4755.86
19.02.	24.0	0.16	0.03	5.00	22.39	12.79	48.51	0.00	18.40	197913.85	4749.91
20.02.	24.0	0.15	0.03	5.00	22.33	13.93	49.31	0.00	18.05	192070.74	4609.72
21.02.	22.0	0.15	0.03	5.00	22.31	14.33	48.71	0.00	19.29	203130.00	4468.85
22.02.	24.0	0.16	0.03	5.00	22.27	12.40	50.63	0.00	19.15	204910.60	4917.85
23.02.	9.5	0.17	0.03	5.00	22.29	14.56	49.38	0.00	18.67	195404.98	1856.35
24.02.	3.0	0.12	0.01	5.00	21.99	6.27	37.60	0.00	6.56	77397.93	232.19
25.02.	12.0	0.12	0.01	5.00	22.16	7.58	41.39	0.00	6.42	73575.40	882.91
26.02.	0.0	----N	----N	----N	----N	----N	----N	----N	----N	----N	----N
27.02.	0.0	----N	----N	----N	----N	----N	----N	----N	----N	----N	----N
28.02.	0.0	----N	----N	----N	----N	----N	----N	----N	----N	----N	----N
MAV Average/ Sum	458.5	0.21	0.04	5.00	22.45	12.04	46.33	0.00	17.78	194636.07	92515.55
Availability in %		100.0 %	100.0 %	100.0 %	100.0 %	100.0 %	100.0 %	100.0 %	100.0 %	100.0 %	100.0 %
DAV Min (steady state)		0.12	0.01	5.00	21.99	6.27	37.42	0.00	6.42	73575.40	232.19
Time		24.02.	24.02.	01.02.	24.02.	24.02.	03.02.	01.02.	25.02.	25.02.	24.02.
DAV Max (steady state)		0.39	0.08	5.00	22.73	14.66	51.41	0.00	19.70	217893.65	5148.73
Time		08.02.	08.02.	01.02.	09.02.	12.02.	12.02.	01.02.	14.02.	04.02.	10.02.
Uncertainty mass (%)			700.0 %								

Operation Hours: 458.5, Steady Op Hours: 435.5, Availability O2: 100.0 %

Legend  
 Letnje - 'S' ili; zimsko - 'W'  
 status postrojenja: Stabilan rad - '1'; Zastoj - '-'; Pokretanje - 'SU'; Zaustavljanje - 'SD'  
 status merjenja: Validno - '1'; Zamenska vrednost - 'S'; Održavanje - 'M'; Kvar - 'X'; Kalibracija - 'C'; Iznad validnog opsega kalibracije - 'P'; Greška - 'F'; Iznad opsega merjenja - 'O'; Ispod opsega merjenja - 'U'; Nema podataka - 'N'  
 Usaglasenost sa GVE: >GVE - 'L'; >GVE+MN - 'I'; >GVE\*1.2 - 'A'; >GVE\*1.2+MN - 'a'; >2\*GVE - 'B'; >2\*GVE+MN - 'b'; Dnevna vazeca srednja vrednost>GVE - 'T'; Dnevna vazeca srednja vrednost>GVE+MN - 't'  
 MN: HF= 1 mg/m<sup>3</sup>; HCl=6 mg/m<sup>3</sup>; NH3=10 mg/m<sup>3</sup>