

| Day | Operation Hours | HF | | | O2 | Sadržaj vlage | T | P | Brzina | Protok | Kolic. Otp. gasa |
|------------------------|-----------------|--------------------|---------|---------|---------|---------------|---------|---------|---------|--------------------|------------------|
| | | mg/Nm ³ | kg/h | Limit | % | % | °C | hPa | m/s | Nm ³ /h | km ³ |
| 01.03. | 8.5 | 1.48 | 0.23 | 5.00 | 23.06 | 22.16 | 50.25 | 997.74 | 17.15 | 161782.97 | 1375.14 |
| 02.03. | 19.0 | 1.45 | 0.23 | 5.00 | 23.11 | 24.09 | 51.98 | 999.17 | 17.33 | 158870.60 | 3018.55 |
| 03.03. | 24.0 | 1.17 | 0.17 | 5.00 | 23.05 | 28.83 | 58.00 | 999.06 | 17.41 | 147014.82 | 3528.34 |
| 04.03. | 24.0 | 0.72 | 0.10 | 5.00 | 23.21 | 28.70 | 58.08 | 996.88 | 17.23 | 145399.43 | 3489.61 |
| 05.03. | 24.0 | 0.47 | 0.07 | 5.00 | 22.82 | 28.28 | 58.87 | 999.17 | 17.29 | 146833.05 | 3523.99 |
| 06.03. | 24.0 | 0.29 | 0.04 | 5.00 | 22.80 | 30.27 | 60.00 | 1002.97 | 16.99 | 140254.91 | 3366.09 |
| 07.03. | 24.0 | 0.22 | 0.03 | 5.00 | 25.06 | 30.21 | 60.18 | 1004.10 | 16.35 | 135188.70 | 3244.51 |
| 08.03. | 22.5 | 0.24 | 0.03 | 5.00 | 24.88 | 30.56 | 59.36 | 1007.85 | 17.45 | 144359.78 | 3248.12 |
| 09.03. | 17.5 | 0.17 | 0.02 | 5.00 | 24.63 | 26.98 | 53.44 | 1003.63 | 15.30 | 128593.21 | 2250.43 |
| 10.03. | 22.5 | 0.17 | 0.02 | 5.00 | 25.16 | 31.33 | 57.37 | 998.95 | 16.74 | 135124.17 | 3040.29 |
| 11.03. | 17.5 | 0.16 | 0.03 | 5.00 | 23.63 | 17.75 | 40.66 | 994.63 | 17.07 | 175161.99 | 3065.35 |
| 12.03. | 24.0 | 0.13 | 0.02 | 5.00 | 22.96 | 15.31 | 42.65 | 999.54 | 18.48 | 194758.98 | 4674.21 |
| 13.03. | 24.0 | 0.14 | 0.02 | 5.00 | 23.42 | 19.87 | 47.04 | 1003.47 | 18.26 | 180553.72 | 4333.32 |
| 14.03. | 23.5 | 0.47 | 0.08 | 5.00 | 24.11 | 23.45 | 50.50 | 1005.92 | 17.56 | 164097.13 | 3856.29 |
| 15.03. | 24.0 | 1.19 | 0.19 | 5.00 | 23.83 | 24.74 | 53.12 | 1005.01 | 17.89 | 163073.96 | 3913.76 |
| 16.03. | 24.0 | 1.74 | 0.28 | 5.00 | 23.98 | 25.47 | 53.09 | 1006.94 | 17.74 | 160387.73 | 3849.33 |
| 17.03. | 24.0 | 0.92 | 0.15 | 5.00 | 23.87 | 24.67 | 52.47 | 1009.82 | 17.76 | 163104.32 | 3914.50 |
| 18.03. | 13.5 | 1.34 | 0.22 | 5.00 | 23.69 | 22.98 | 50.90 | 1005.90 | 16.69 | 154453.87 | 2085.14 |
| 19.03. | 23.0 | 1.45 | 0.23 | 5.00 | 24.09 | 23.10 | 51.56 | 1008.31 | 17.15 | 161229.49 | 3708.29 |
| 20.03. | 24.0 | 1.02 | 0.16 | 5.00 | 23.99 | 25.50 | 54.64 | 1012.15 | 17.04 | 154311.99 | 3703.52 |
| 21.03. | 24.0 | 0.51 | 0.08 | 5.00 | 24.00 | 24.89 | 53.59 | 1008.76 | 16.84 | 153754.85 | 3690.18 |
| 22.03. | 24.0 | 0.54 | 0.08 | 5.00 | 24.14 | 25.12 | 53.57 | 1006.94 | 16.72 | 151811.51 | 3643.50 |
| 23.03. | 24.0 | 0.52 | 0.08 | 5.00 | 24.14 | 25.29 | 53.97 | 998.82 | 16.72 | 150129.67 | 3603.12 |
| 24.03. | 24.0 | 0.55 | 0.09 | 5.00 | 23.84 | 21.93 | 49.48 | 998.28 | 16.73 | 158876.91 | 3813.07 |
| 25.03. | 20.0 | 0.55 | 0.09 | 5.00 | 23.85 | 21.12 | 47.85 | 998.56 | 16.89 | 163167.94 | 3263.33 |
| 26.03. | 24.0 | 0.50 | 0.08 | 5.00 | 24.02 | 22.71 | 50.19 | 995.19 | 17.25 | 161310.00 | 3871.43 |
| 27.03. | 4.5 | 0.64 | 0.10 | 5.00 | 24.26 | 23.61 | 49.93 | 989.67 | 16.64 | 152880.93 | 687.95 |
| 28.03. | 0.0 | ----N | ----N | ----N | ----N | ----N | ----N | ----N | ----N | ----N | ----N |
| 29.03. | 0.0 | ----N | ----N | ----N | ----N | ----N | ----N | ----N | ----N | ----N | ----N |
| 30.03. | 0.0 | ----N | ----N | ----N | ----N | ----N | ----N | ----N | ----N | ----N | ----N |
| 31.03. | 0.0 | ----N | ----N | ----N | ----N | ----N | ----N | ----N | ----N | ----N | ----N |
| MAV Average/ Sum | 576.0 | 0.69 | 0.11 | 5.00 | 23.84 | 24.77 | 52.69 | 1002.13 | 17.14 | 155795.80 | 89761.36 |
| Availability in % | | 100.0 % | 100.0 % | 100.0 % | 100.0 % | 100.0 % | 100.0 % | 100.0 % | 100.0 % | 100.0 % | 100.0 % |
| DAV Min (steady state) | | 0.13 | 0.02 | 5.00 | 22.80 | 15.31 | 40.66 | 989.67 | 15.30 | 128593.21 | 687.95 |
| Time | | 12.03. | 09.03. | 01.03. | 06.03. | 12.03. | 11.03. | 27.03. | 09.03. | 09.03. | 27.03. |
| DAV Max (steady state) | | 1.74 | 0.28 | 5.00 | 25.16 | 31.33 | 60.18 | 1012.15 | 18.48 | 194758.98 | 4674.21 |
| Time | | 16.03. | 16.03. | 01.03. | 10.03. | 10.03. | 07.03. | 20.03. | 12.03. | 12.03. | 12.03. |
| Uncertainty mass (%) | | | 254.6 % | | | | | | | | |

Operation Hours: 576.0, Steady Op Hours: 557.0, Availability O2: 100.0 %

Legend
 Letrije - 'S' ili: zimsko - 'W'
 status postrojenja: Stabilan rad - '-'; Zastoj - '-'; Pokretanje - 'SU'; Zaustavljanje - 'SD'
 status merenja: Validno - '-'; Zamenska vrednost - 'S'; Odrzavanje - 'M'; Kvar - 'X'; Kalibracija - 'C'; Iznad validnog opsega kalibracije - 'P'; Greška - 'F'; Iznad opsega merenja - 'O'; Ispod opsega merenja - 'U'; Nema podataka - 'N'
 Usaglasenost sa GVE: >GVE - 'L'; >GVE+MN - 'I'; >GVE*1.2 - 'A'; >GVE*1.2+MN - 'a'; >2*GVE - 'B'; >2*GVE+MN - 'b'; Dnevna vazeca srednja vrednost>GVE - 'T'; Dnevna vazeca srednja vrednost>GVE+MN - 't'
 MN: HF= 1 mg/m³; HCl=6 mg/m³; NH3=10 mg/m³