

| Day                    | Operation Hours | HF                 |         |         | HCl                |         |         | NH3                |         |         | Prasina            |         |         |
|------------------------|-----------------|--------------------|---------|---------|--------------------|---------|---------|--------------------|---------|---------|--------------------|---------|---------|
|                        |                 | mg/Nm <sup>3</sup> | kg/h    | Limit   | mg/Nm <sup>3</sup> | kg/h    | Limit   | mg/Nm <sup>3</sup> | kg/h    | Limit   | mg/Nm <sup>3</sup> | kg/h    | Limit   |
| 01.08.                 | 19.0            | 2.10               | 0.43    | 5.00    | 4.80               | 0.98    | 20.00   | 4.02               | 0.80    | 30.00   | 1.45               | 0.29    | 20.00   |
| 02.08.                 | 20.5            | 2.43               | 0.42    | 5.00    | 2.78               | 0.49    | 20.00   | 10.11              | 1.76    | 30.00   | 1.26               | 0.23    | 20.00   |
| 03.08.                 | 24.0            | 3.03               | 0.53    | 5.00    | 1.75               | 0.31    | 20.00   | 14.82              | 2.61    | 30.00   | 1.54               | 0.27    | 20.00   |
| 04.08.                 | 24.0            | 3.40               | 0.61    | 5.00    | 1.56               | 0.28    | 20.00   | 19.81              | 3.53    | 30.00   | 1.55               | 0.28    | 20.00   |
| 05.08.                 | 24.0            | 2.77               | 0.50    | 5.00    | 0.79               | 0.14    | 20.00   | 10.02              | 1.79    | 30.00   | 1.41               | 0.25    | 20.00   |
| 06.08.                 | 24.0            | 2.58               | 0.46    | 5.00    | 0.41               | 0.07    | 20.00   | 11.90              | 2.10    | 30.00   | 1.07               | 0.19    | 20.00   |
| 07.08.                 | 24.0            | 1.29               | 0.23    | 5.00    | 0.17               | 0.03    | 20.00   | 7.90               | 1.40    | 30.00   | 1.03               | 0.18    | 20.00   |
| 08.08.                 | 24.0            | 1.44               | 0.25    | 5.00    | 3.04               | 0.54    | 20.00   | 10.10              | 1.78    | 30.00   | 1.43               | 0.25    | 20.00   |
| 09.08.                 | 23.5            | 1.00               | 0.16    | 5.00    | 2.29               | 0.30    | 20.00   | 9.17               | 1.50    | 30.00   | 1.54               | 0.23    | 20.00   |
| 10.08.                 | 12.0            | 1.52               | 0.26    | 5.00    | 6.55               | 1.06    | 20.00   | 11.55              | 1.94    | 30.00   | 2.30               | 0.38    | 20.00   |
| 11.08.                 | 18.5            | 3.01               | 0.52    | 5.00    | 1.73               | 0.31    | 20.00   | 18.17              | 3.16    | 30.00   | 1.34               | 0.25    | 20.00   |
| 12.08.                 | 24.0            | 3.33               | 0.56    | 5.00    | 0.51               | 0.09    | 20.00   | 17.06              | 2.88    | 30.00   | 0.86               | 0.14    | 20.00   |
| 13.08.                 | 24.0            | 2.17               | 0.36    | 5.00    | 1.84               | 0.28    | 20.00   | 12.94              | 2.17    | 30.00   | 0.83               | 0.14    | 20.00   |
| 14.08.                 | 24.0            | 1.02               | 0.16    | 5.00    | 6.92               | 1.10    | 20.00   | 12.69              | 1.98    | 30.00   | 1.49               | 0.23    | 20.00   |
| 15.08.                 | 24.0            | 0.87               | 0.14    | 5.00    | 3.46               | 0.56    | 20.00   | 10.46              | 1.70    | 30.00   | 2.79               | 0.45    | 20.00   |
| 16.08.                 | 24.0            | 0.72               | 0.12    | 5.00    | 5.61               | 0.91    | 20.00   | 12.39              | 1.99    | 30.00   | 4.57               | 0.73    | 20.00   |
| 17.08.                 | 24.0            | 1.61               | 0.27    | 5.00    | 0.55               | 0.09    | 20.00   | 7.01               | 1.15    | 30.00   | 7.14               | 1.18    | 20.00   |
| 18.08.                 | 9.5             | 2.82               | 0.48    | 5.00    | 0.89               | 0.15    | 20.00   | 7.60               | 1.29    | 30.00   | 5.09               | 0.86    | 20.00   |
| 19.08.                 | 20.0            | 2.96               | 0.56    | 5.00    | 2.79               | 0.53    | 20.00   | 14.97              | 2.81    | 30.00   | 8.55               | 1.62    | 20.00   |
| 20.08.                 | 24.0            | 3.08               | 0.57    | 5.00    | 3.16               | 0.58    | 20.00   | 15.00              | 2.76    | 30.00   | 8.77               | 1.62    | 20.00   |
| 21.08.                 | 20.5            | 2.47               | 0.40    | 5.00    | 2.60               | 0.34    | 20.00   | 13.28              | 2.16    | 30.00   | 6.13               | 0.92    | 20.00   |
| 22.08.                 | 24.0            | 3.82               | 0.59    | 5.00    | 0.56               | 0.09    | 20.00   | 17.71              | 2.75    | 30.00   | 5.37               | 0.84    | 20.00   |
| 23.08.                 | 24.0            | 2.95               | 0.47    | 5.00    | 7.13               | 1.14    | 20.00   | 19.14              | 3.06    | 30.00   | 15.82              | 2.53    | 20.00   |
| 24.08.                 | 24.0            | 2.55               | 0.40    | 5.00    | 5.66               | 0.89    | 20.00   | 17.53              | 2.76    | 30.00   | 13.11              | 2.06    | 20.00   |
| 25.08.                 | 24.0            | 1.92               | 0.30    | 5.00    | 3.84               | 0.58    | 20.00   | 13.51              | 2.13    | 30.00   | 9.23               | 1.47    | 20.00   |
| 26.08.                 | 24.0            | 2.51               | 0.39    | 5.00    | 2.20               | 0.35    | 20.00   | 20.08              | 3.13    | 30.00   | 8.82               | 1.38    | 20.00   |
| 27.08.                 | 24.0            | 3.52               | 0.56    | 5.00    | 0.42               | 0.07    | 20.00   | 21.45              | 3.44    | 30.00   | 9.30               | 1.49    | 20.00   |
| 28.08.                 | 24.0            | 2.32               | 0.36    | 5.00    | 0.67               | 0.06    | 20.00   | 13.24              | 1.96    | 30.00   | 10.63              | 1.47    | 20.00   |
| 29.08.                 | 24.0            | 2.03               | 0.32    | 5.00    | 0.82               | 0.11    | 20.00   | 15.52              | 2.38    | 30.00   | 11.20              | 1.61    | 20.00   |
| 30.08.                 | 24.0            | 2.58               | 0.39    | 5.00    | 0.25               | 0.02    | 20.00   | 16.15              | 2.34    | 30.00   | 14.69              | 2.07    | 20.00   |
| 31.08.                 | 24.0            | 2.39               | 0.38    | 5.00    | 0.33               | 0.05    | 20.00   | 14.81              | 2.35    | 30.00   | 15.80              | 2.50    | 20.00   |
| MAV Average/ Sum       | 695.5           | 2.33               | 0.39    | 5.00    | 2.44               | 0.40    | 20.00   | 13.55              | 2.24    | 30.00   | 5.68               | 0.91    | 20.00   |
| Availability in %      |                 | 100.0 %            | 100.0 % | 100.0 % | 100.0 %            | 100.0 % | 100.0 % | 100.0 %            | 100.0 % | 100.0 % | 100.0 %            | 100.0 % | 100.0 % |
| DAV Min (steady state) |                 | 0.72               | 0.12    | 5.00    | 0.17               | 0.02    | 20.00   | 4.02               | 0.80    | 30.00   | 0.83               | 0.14    | 20.00   |
| Time                   |                 | 16.08.             | 16.08.  | 01.08.  | 07.08.             | 30.08.  | 01.08.  | 01.08.             | 01.08.  | 01.08.  | 13.08.             | 12.08.  | 01.08.  |
| DAV Max (steady state) |                 | 3.82               | 0.61    | 5.00    | 7.13               | 1.14    | 20.00   | 21.45              | 3.53    | 30.00   | 15.82              | 2.53    | 20.00   |
| Time                   |                 | 22.08.             | 04.08.  | 01.08.  | 23.08.             | 23.08.  | 01.08.  | 27.08.             | 04.08.  | 01.08.  | 23.08.             | 23.08.  | 01.08.  |
| Uncertainty mass (%)   |                 |                    | 71.8 %  |         |                    | 395.0 % |         |                    | 116.5 % |         |                    |         |         |

Operation Hours: 695.5, Steady Op Hours: 666.0, Availability O2: 100.0 %

Legend  
 Letrije - 'S' ili: zimsko - 'W'  
 status postrojenja: Stabilan rad - '1'; Zastoj - '-'; Pokretanje - 'SU'; Zaustavljanje - 'SD'  
 status merjenja: Validno - '1'; Zamenska vrednost - 'S'; Održavanje - 'M'; Kvar - 'X'; Kalibracija - 'C'; Iznad validnog opsega kalibracije - 'P'; Greška - 'F'; Iznad opsega merjenja - 'O'; Ispod opsega merjenja - 'U'; Nema podataka - 'N'  
 Usaglasenost sa GVE: >GVE - 'L'; >GVE+MN - '1'; >GVE\*1.2 - 'A'; >GVE\*1.2+MN - 'a'; >2\*GVE - 'B'; >2\*GVE+MN - 'b'; Dnevna važeća srednja vrednost>GVE - 'T'; Dnevna važeća srednja vrednost>GVE+MN - 't'  
 MN: HF= 1 mg/m<sup>3</sup>; HCl=6 mg/m<sup>3</sup>; NH3=10 mg/m<sup>3</sup>

| Day                    | Operation Hours | O2<br>% | Sadržaj vlage<br>% | T<br>°C | P<br>hPa | Brzina<br>m/s | Protok<br>Nm <sup>3</sup> /h | Kolic. Otp. gasa<br>km <sup>3</sup> |  |
|------------------------|-----------------|---------|--------------------|---------|----------|---------------|------------------------------|-------------------------------------|--|
| 01.08.                 | 19.0            | 23.16   | 11.23              | 43.93   | 1002.70  | 17.30         | 203310.50                    | 3862.93                             |  |
| 02.08.                 | 20.5            | 21.83   | 13.34              | 49.72   | 998.08   | 16.01         | 180288.12                    | 3695.90                             |  |
| 03.08.                 | 24.0            | 21.42   | 16.30              | 52.43   | 1000.43  | 16.30         | 176231.13                    | 4229.52                             |  |
| 04.08.                 | 24.0            | 21.39   | 15.88              | 51.76   | 1005.56  | 16.32         | 178640.12                    | 4287.37                             |  |
| 05.08.                 | 24.0            | 21.41   | 16.16              | 52.33   | 1006.64  | 16.40         | 178773.15                    | 4290.56                             |  |
| 06.08.                 | 24.0            | 21.91   | 16.90              | 53.30   | 1007.67  | 16.44         | 177301.69                    | 4255.25                             |  |
| 07.08.                 | 24.0            | 21.97   | 16.66              | 52.60   | 1009.32  | 16.30         | 176877.50                    | 4245.07                             |  |
| 08.08.                 | 24.0            | 20.72   | 16.65              | 52.75   | 1008.80  | 16.24         | 176108.63                    | 4226.58                             |  |
| 09.08.                 | 23.5            | 21.02   | 14.98              | 50.31   | 1008.24  | 14.21         | 155228.73                    | 3647.85                             |  |
| 10.08.                 | 12.0            | 21.10   | 12.41              | 46.76   | 1007.18  | 13.73         | 156027.32                    | 1872.32                             |  |
| 11.08.                 | 18.5            | 20.88   | 16.47              | 52.89   | 1008.12  | 16.15         | 175334.63                    | 3243.67                             |  |
| 12.08.                 | 24.0            | 20.60   | 17.72              | 54.31   | 1007.38  | 15.85         | 168630.33                    | 4047.12                             |  |
| 13.08.                 | 24.0            | 20.47   | 17.58              | 53.75   | 1005.20  | 15.75         | 167915.46                    | 4029.98                             |  |
| 14.08.                 | 24.0            | 21.11   | 14.98              | 50.69   | 1004.08  | 13.77         | 150768.46                    | 3618.45                             |  |
| 15.08.                 | 24.0            | 21.61   | 18.11              | 54.74   | 1004.42  | 15.43         | 162837.19                    | 3908.08                             |  |
| 16.08.                 | 24.0            | 21.33   | 19.11              | 55.88   | 1001.05  | 15.50         | 160437.36                    | 3850.51                             |  |
| 17.08.                 | 24.0            | 20.47   | 17.89              | 53.45   | 998.66   | 15.69         | 165465.02                    | 3971.15                             |  |
| 18.08.                 | 9.5             | 20.55   | 14.87              | 48.42   | 1001.61  | 15.27         | 169091.38                    | 1606.38                             |  |
| 19.08.                 | 20.0            | 20.26   | 13.91              | 48.67   | 1002.58  | 16.79         | 189175.46                    | 3783.51                             |  |
| 20.08.                 | 24.0            | 19.37   | 17.99              | 53.61   | 998.16   | 17.52         | 184263.10                    | 4422.31                             |  |
| 21.08.                 | 20.5            | 20.10   | 16.31              | 50.07   | 994.68   | 14.39         | 153129.77                    | 3139.13                             |  |
| 22.08.                 | 24.0            | 20.77   | 20.51              | 56.54   | 996.34   | 15.42         | 155686.04                    | 3736.48                             |  |
| 23.08.                 | 24.0            | 19.37   | 20.32              | 56.08   | 1002.39  | 15.68         | 159895.21                    | 3837.45                             |  |
| 24.08.                 | 24.0            | 18.99   | 19.44              | 54.27   | 1006.67  | 15.13         | 156935.05                    | 3766.43                             |  |
| 25.08.                 | 24.0            | 19.72   | 17.71              | 54.18   | 1006.83  | 15.12         | 160875.24                    | 3861.00                             |  |
| 26.08.                 | 24.0            | 20.61   | 20.97              | 57.12   | 1004.13  | 15.47         | 156204.54                    | 3748.90                             |  |
| 27.08.                 | 24.0            | 20.61   | 19.58              | 54.88   | 1003.44  | 15.56         | 160930.15                    | 3862.33                             |  |
| 28.08.                 | 24.0            | 21.60   | 17.46              | 51.52   | 1000.50  | 13.58         | 141707.15                    | 3400.96                             |  |
| 29.08.                 | 24.0            | 21.59   | 16.46              | 50.76   | 995.91   | 13.79         | 145987.81                    | 3503.68                             |  |
| 30.08.                 | 24.0            | 21.36   | 16.69              | 53.37   | 996.11   | 13.90         | 142215.15                    | 3413.21                             |  |
| 31.08.                 | 24.0            | 20.95   | 19.87              | 54.82   | 998.67   | 15.42         | 158179.05                    | 3796.33                             |  |
| MAV Average/ Sum       | 695.5           | 20.91   | 16.98              | 52.45   | 1002.95  | 15.50         | 165950.01                    | 115160.41                           |  |
| Availability in %      |                 | 100.0 % | 100.0 %            | 100.0 % | 100.0 %  | 100.0 %       | 100.0 %                      | 100.0 %                             |  |
| DAV Min (steady state) |                 | 18.89   | 11.23              | 43.93   | 994.68   | 13.58         | 141707.15                    | 1606.38                             |  |
| Time                   |                 | 24.08.  | 01.08.             | 01.08.  | 21.08.   | 28.08.        | 28.08.                       | 18.08.                              |  |
| DAV Max (steady state) |                 | 23.16   | 20.97              | 57.12   | 1009.32  | 17.52         | 203310.50                    | 4422.31                             |  |
| Time                   |                 | 01.08.  | 26.08.             | 26.08.  | 07.08.   | 20.08.        | 01.08.                       | 20.08.                              |  |
| Uncertainty mass (%)   |                 |         |                    |         |          |               |                              |                                     |  |

Operation Hours: 695.5, Steady Op Hours: 666.0, Availability O2: 100.0 %

Legend  
 Letrije - 'S' ili: zimsko - 'W'  
 status postrojenja: Stabilan rad - '1'; Zastoj - '-'; Pokretanje - 'SU'; Zauštavljanje - 'SD'  
 status merenja: Validno - '1'; Zamenska vrednost - 'S'; Održavanje - 'M'; Kvar - 'X'; Kalibracija - 'C'; Iznad validnog opsega kalibracije - 'P'; Greška - 'F'; Iznad opsega merenja - 'O'; Ispod opsega merenja - 'U'; Nema podataka - 'N'  
 Usaglasenost sa GVE: >GVE - 'L'; >GVE+MN - 'I'; >GVE\*1.2 - 'A'; >GVE\*1.2+MN - 'a'; >2\*GVE - 'B'; >2\*GVE+MN - 'b'; Dnevna važeća srednja vrednost>GVE - 'T'; Dnevna važeća srednja vrednost>GVE+MN - 't'  
 MN: HF= 1 mg/m<sup>3</sup>; HCl=6 mg/m<sup>3</sup>; NH3=10 mg/m<sup>3</sup>

Created on/at 1.9.2025./ 00:02, created according to ČNORM M9412:2008 (EmiProtocol Version V 6.5, Parameter Version V1)