

| Date | Block Flag | HF | | | HCl | | | NH3 | | | Prasina | | |
|------------------------|------------|--------------------|------------|------------|--------------------|------------|------------|--------------------|------------|------------|--------------------|------------|------------|
| | | mg/Nm ³ | kg/h | Limit | mg/Nm ³ | kg/h | Limit | mg/Nm ³ | kg/h | Limit | mg/Nm ³ | kg/h | Limit |
| 01.06.2026 | | 1.50 | 0.23 | 5.00 | 0.82 | 0.07 | 20.00 | 9.88 | 1.37 | 30.00 | 0.63 | 0.09 | 20.00 |
| 02.06.2026 | | 1.57 | 0.22 | 5.00 | 1.65 | 0.23 | 20.00 | 12.06 | 1.71 | 30.00 | 1.10 | 0.16 | 20.00 |
| 03.06.2026 | | 2.10 | 0.30 | 5.00 | 2.15 | 0.30 | 20.00 | 13.04 | 1.84 | 30.00 | 1.41 | 0.20 | 20.00 |
| 04.06.2026 | | 1.83 | 0.26 | 5.00 | 1.56 | 0.10 | 20.00 | 11.27 | 1.47 | 30.00 | 2.34 | 0.29 | 20.00 |
| 05.06.2026 | | 2.07 | 0.30 | 5.00 | 0.38 | 0.06 | 20.00 | 9.21 | 1.34 | 30.00 | 1.49 | 0.21 | 20.00 |
| 06.06.2026 | | 1.90 | 0.25 | 5.00 | 0.71 | 0.02 | 20.00 | 9.82 | 1.20 | 30.00 | 1.61 | 0.21 | 20.00 |
| 07.06.2026 | | 1.57 | 0.21 | 5.00 | 0.80 | 0.07 | 20.00 | 6.47 | 0.83 | 30.00 | 1.88 | 0.25 | 20.00 |
| 08.06.2026 | | 0.45 | 0.06 | 5.00 | 1.06 | 0.15 | 20.00 | 4.66 | 0.65 | 30.00 | 2.58 | 0.34 | 20.00 |
| 09.06.2026 | | 1.68 | 0.23 | 5.00 | 0.45 | 0.06 | 20.00 | 1.90 | 0.26 | 30.00 | 0.68 | 0.09 | 20.00 |
| 10.06.2026 | | 1.77 | 0.22 | 5.00 | 0.86 | 0.11 | 20.00 | 4.47 | 0.57 | 30.00 | 4.84 | 0.63 | 20.00 |
| 11.06.2026 | | 0.37 | 0.05 | 5.00 | 1.15 | 0.13 | 20.00 | 2.27 | 0.27 | 30.00 | 4.86 | 0.61 | 20.00 |
| 12.06.2026 | | 0.90 | 0.12 | 5.00 | 0.25 | 0.03 | 20.00 | 4.61 | 0.60 | 30.00 | 3.95 | 0.51 | 20.00 |
| 13.06.2026 | | 0.53 | 0.07 | 5.00 | 0.79 | 0.11 | 20.00 | 5.62 | 0.77 | 30.00 | 1.87 | 0.25 | 20.00 |
| 14.06.2026 | | 0.68 | 0.08 | 5.00 | 1.15 | 0.12 | 20.00 | 8.74 | 1.06 | 30.00 | 1.40 | 0.16 | 20.00 |
| 15.06.2026 | | 1.39 | 0.18 | 5.00 | 0.64 | 0.09 | 20.00 | 14.34 | 1.91 | 30.00 | 1.09 | 0.14 | 20.00 |
| 16.06.2026 | | 0.35 | 0.04 | 5.00 | 0.50 | 0.06 | 20.00 | 10.32 | 1.24 | 30.00 | 0.62 | 0.07 | 20.00 |
| 17.06.2026 | | 0.91 | 0.13 | 5.00 | 2.28 | 0.35 | 20.00 | 5.00 | 0.72 | 30.00 | 0.97 | 0.14 | 20.00 |
| 18.06.2026 | | 2.66 | 0.25 | 5.00 | 4.36 | 0.39 | 20.00 | 10.50 | 0.97 | 30.00 | 2.36 | 0.23 | 20.00 |
| 19.06.2026 | | 2.53 | 0.22 | 5.00 | 2.21 | 0.17 | 20.00 | 12.67 | 1.03 | 30.00 | 1.75 | 0.14 | 20.00 |
| 20.06.2026 | | 1.49 | 0.16 | 5.00 | 0.97 | 0.11 | 20.00 | 11.26 | 1.22 | 30.00 | 2.20 | 0.25 | 20.00 |
| 21.06.2026 | | 1.91 | 0.24 | 5.00 | 0.86 | 0.11 | 20.00 | 12.26 | 1.55 | 30.00 | 1.84 | 0.23 | 20.00 |
| 22.06.2026 | | 1.30 | 0.18 | 5.00 | 1.68 | 0.24 | 20.00 | 7.10 | 0.97 | 30.00 | 1.33 | 0.18 | 20.00 |
| 23.06.2026 | | 0.89 | 0.12 | 5.00 | 3.27 | 0.43 | 20.00 | 6.10 | 0.80 | 30.00 | 1.06 | 0.14 | 20.00 |
| 24.06.2026 | | 1.76 | 0.27 | 5.00 | 2.28 | 0.34 | 20.00 | 7.89 | 1.19 | 30.00 | 1.29 | 0.19 | 20.00 |
| 25.06.2026 | | | | | | | | | | | | | |
| 26.06.2026 | | | | | | | | | | | | | |
| 27.06.2026 | | | | | | | | | | | | | |
| 28.06.2026 | | | | | | | | | | | | | |
| 29.06.2026 | | | | | | | | | | | | | |
| 30.06.2026 | | | | | | | | | | | | | |
| MAV Average/ Sum | 23 Stat. | | | | | | | | | | | | |
| Avaliability in % | | 100.0 % | 100.0 % | 100.0 % | 100.0 % | 100.0 % | 100.0 % | 100.0 % | 100.0 % | 100.0 % | 100.0 % | 100.0 % | 100.0 % |
| DAV Min (steady state) | | 0.35 | 0.04 | 5.00 | 0.25 | 0.02 | 20.00 | 1.90 | 0.26 | 30.00 | 0.62 | 0.07 | 20.00 |
| Time | | 16.06.2026 | 16.06.2026 | 01.06.2026 | 12.06.2026 | 06.06.2026 | 01.06.2026 | 09.06.2026 | 09.06.2026 | 01.06.2026 | 16.06.2026 | 16.06.2026 | 01.06.2026 |
| DAV Max (steady state) | | 2.66 | 0.30 | 5.00 | 4.36 | 0.43 | 20.00 | 14.34 | 1.91 | 30.00 | 4.86 | 0.63 | 20.00 |
| Time | | 18.06.2026 | 03.06.2026 | 01.06.2026 | 18.06.2026 | 23.06.2026 | 01.06.2026 | 15.06.2026 | 15.06.2026 | 01.06.2026 | 11.06.2026 | 10.06.2026 | 01.06.2026 |

Operation Hours: 505.0, Steady Op Hours: 472.5, Availability O2: 100.0 %

Legend
 Letrije - 'S' ili: zimsko - 'W'
 status postrojenja: Stabilan rad - ' '; Zastoj - '-'; Pokretanje - 'SU'; Zaustavljanje - 'SD'
 status merjenja: Validno - ' '; Zamenska vrednost - 'S'; Održavanje - 'M'; Kvar - 'X'; Kalibracija - 'C'; Iznad validnog opsega kalibracije - 'P'; Greška - 'F'; Iznad opsega merjenja - 'O'; Ispod opsega merjenja - 'U'; Nema podataka - 'N'
 Usaglašenost sa GVE: >GVE - 'L'; >GVE+MN - 'I'; >GVE*1.2 - 'A'; >GVE*1.2+MN - 'a'; >2*GVE - 'B'; >2*GVE+MN - 'b'; Dnevna važeća srednja vrednost>GVE - 'T'; Dnevna važeća srednja vrednost>GVE+MN - 't'
 MN: HF= 1 mg/m³; HCl=6 mg/m³; NH3=10 mg/m³

Created on/ at 25.6.2026./ 00:02, created according to ÖNORM M9412:2008 (EmiProtocol Version V 6.5, Parameter Version V1)

| Date | Block Flag | O2 % | Sadržaj vlage % | T °C | P hPa | Protok km ³ /h | Kolic. Otp. gasa km ³ |
|------------------------|------------|------------|--------------------|------------|------------|------------------------------|-------------------------------------|
| 01.06.2026 | | 18.60 | 11.62 | 50.03 | 1000.47 | 143.36 | 3440.63 |
| 02.06.2026 | | 18.80 | 14.19 | 54.47 | 1000.83 | 142.18 | 3412.25 |
| 03.06.2026 | | 18.30 | 13.63 | 53.67 | 995.94 | 140.93 | 3382.39 |
| 04.06.2026 | | 17.06 | 12.74 | 50.87 | 998.48 | 120.98 | 2903.45 |
| 05.06.2026 | | 17.75 | 11.72 | 50.11 | 999.60 | 145.42 | 3489.98 |
| 06.06.2026 | | 18.31 | 11.89 | 50.35 | 1004.66 | 123.49 | 2963.71 |
| 07.06.2026 | | 18.34 | 10.78 | 48.12 | 1006.87 | 126.13 | 2838.08 |
| 08.06.2026 | | 18.67 | 9.41 | 46.16 | 1006.83 | 140.87 | 1408.74 |
| 09.06.2026 | | 19.83 | 11.00 | 49.13 | 1000.63 | 136.42 | 2114.41 |
| 10.06.2026 | | 18.43 | 15.78 | 57.00 | 999.59 | 127.64 | 3063.44 |
| 11.06.2026 | | 18.49 | 14.03 | 54.26 | 1003.98 | 121.54 | 2856.13 |
| 12.06.2026 | | 17.78 | 13.99 | 54.36 | 1008.62 | 129.89 | 3117.32 |
| 13.06.2026 | | 17.63 | 14.44 | 54.77 | 1006.70 | 136.29 | 3270.90 |
| 14.06.2026 | | 17.99 | 12.45 | 51.16 | 999.62 | 111.61 | 2678.59 |
| 15.06.2026 | | 18.32 | 13.30 | 52.72 | 1002.29 | 133.88 | 3146.26 |
| 16.06.2026 | | 22.87 | 6.31 | 34.65 | 1003.83 | 120.30 | 60.15 |
| 17.06.2026 | | 20.57 | 9.86 | 47.74 | 1005.56 | 145.70 | 437.12 |
| 18.06.2026 | | 19.88 | 15.38 | 55.87 | 1006.21 | 96.28 | 2166.29 |
| 19.06.2026 | | 20.42 | 14.71 | 54.48 | 1006.53 | 78.13 | 1875.22 |
| 20.06.2026 | | 20.99 | 15.22 | 55.50 | 1007.89 | 109.83 | 2635.90 |
| 21.06.2026 | | 21.14 | 14.77 | 55.16 | 1009.60 | 126.68 | 3040.32 |
| 22.06.2026 | | 20.03 | 13.31 | 53.13 | 1006.51 | 136.54 | 3276.93 |
| 23.06.2026 | | 21.17 | 12.08 | 50.99 | 1004.00 | 132.28 | 3174.74 |
| 24.06.2026 | | 21.13 | 14.01 | 54.48 | 1003.41 | 150.53 | 3612.68 |
| 25.06.2026 | | | | | | | |
| 26.06.2026 | | | | | | | |
| 27.06.2026 | | | | | | | |
| 28.06.2026 | | | | | | | |
| 29.06.2026 | | | | | | | |
| 30.06.2026 | | | | | | | |
| MAV Average/ Sum | 23 Stat. | | | | | | |
| Avalability in % | | 100.0 % | 100.0 % | 100.0 % | 100.0 % | 100.0 % | 100.0 % |
| DAV Min (steady state) | | 16.80 | 6.31 | 34.65 | 995.94 | 78.13 | 60.15 |
| Time | | 02.06.2026 | 16.06.2026 | 16.06.2026 | 03.06.2026 | 19.06.2026 | 16.06.2026 |
| DAV Max (steady state) | | 22.87 | 15.78 | 57.00 | 1009.60 | 150.53 | 3612.68 |
| Time | | 16.06.2026 | 10.06.2026 | 10.06.2026 | 21.06.2026 | 24.06.2026 | 24.06.2026 |

Operation Hours: 505.0, Steady Op Hours: 472.5, Availability O2: 100.0 %

Legend
 Letnje - 'S' ili; zimsko - 'W'
 status postrojenja: Stabilan rad - '1'; Zastoj - '-'; Pokretanje - 'SU'; Zaustavljanje - 'SD'
 status merjenja: Validno - '1'; Zamenska vrednost - 'S'; Održavanje - 'M'; Kvar - 'X'; Kalibracija - 'C'; Iznad validnog opsega kalibracije - 'P'; Greška - 'F'; Iznad opsega merjenja - 'O'; Ispod opsega merjenja - 'U'; Nema podataka - 'N'
 Usaglašenost sa GVE: >GVE - 'L'; >GVE+MN - 'I'; >GVE*1.2 - 'A'; >GVE*1.2+MN - 'a'; >2*GVE - 'B'; >2*GVE+MN - 'b'; Dnevna važeća srednja vrednost>GVE - 'T'; Dnevna važeća srednja vrednost>GVE+MN - 't'
 MN: HF= 1 mg/m³; HCl=6 mg/m³; NH3=10 mg/m³