

Date	Block Flag	HF			HCl			NH3			Prasina			
		mg/Nm³	kg/h	Limit	mg/Nm³	kg/h	Limit	mg/Nm³	kg/h	Limit	mg/Nm3	kg/h	Limit	
01.08.2026		0.75	0.13	5.00	3.52	0.60	20.00	6.33	1.08	30.00	1.97	0.34	20.00	
02.08.2026		0.43	0.08	5.00	6.81	1.21	20.00	5.03	0.90	30.00	2.02	0.37	20.00	
03.08.2026		0.36	0.03	5.00	3.88	0.36	20.00	5.76	0.46	30.00	1.54	0.13	20.00	
04.08.2026		0.32	0.06	5.00	0.92	0.18	20.00	2.63	0.53	30.00	1.28	0.26	20.00	
05.08.2026		0.33	0.06	5.00	2.22	0.43	20.00	1.87	0.37	30.00	1.29	0.25	20.00	
06.08.2026		0.32	0.06	5.00	0.89	0.17	20.00	2.92	0.56	30.00	1.29	0.25	20.00	
07.08.2026		0.30	0.06	5.00	0.72	0.14	20.00	3.06	0.59	30.00	1.29	0.25	20.00	
08.08.2026		0.30	0.06	5.00	1.81	0.35	20.00	2.79	0.54	30.00	1.24	0.24	20.00	
09.08.2026		0.30	0.03	5.00	2.01	0.16	20.00	2.17	0.23	30.00	1.19	0.13	20.00	
10.08.2026		1.39	0.24	5.00	3.76	0.67	20.00	6.31	1.10	30.00	2.47	0.43	20.00	
11.08.2026		0.93	0.16	5.00	2.29	0.39	20.00	5.62	0.95	30.00	2.54	0.43	20.00	
12.08.2026		0.35	0.06	5.00	2.07	0.36	20.00	3.08	0.53	30.00	2.04	0.35	20.00	
13.08.2026		0.33	0.06	5.00	1.51	0.26	20.00	2.63	0.46	30.00	2.02	0.35	20.00	
14.08.2026		0.50	0.09	5.00	1.21	0.21	20.00	2.45	0.43	30.00	2.30	0.40	20.00	
15.08.2026		0.49	0.08	5.00	0.71	0.12	20.00	2.08	0.36	30.00	1.87	0.32	20.00	
16.08.2026		0.47	0.08	5.00	0.59	0.10	20.00	1.62	0.28	30.00	2.22	0.38	20.00	
17.08.2026		3.08	0.53	5.00	4.84	0.83	20.00	13.16	2.23	30.00	3.26	0.58	20.00	
18.08.2026		3.65	0.60	5.00	5.79	0.96	20.00	19.10	3.15	30.00	3.22	0.53	20.00	
19.08.2026		2.82	0.47	5.00	6.58	1.09	20.00	16.83	2.79	30.00	2.94	0.49	20.00	
20.08.2026		3.09	0.51	5.00	8.86	1.48	20.00	14.89	2.47	30.00	2.90	0.49	20.00	
21.08.2026		1.88	0.31	5.00	9.84	1.73	20.00	14.02	2.43	30.00	2.39	0.42	20.00	
22.08.2026		0.91	0.15	5.00	7.47	1.26	20.00	10.97	1.85	30.00	2.18	0.38	20.00	
23.08.2026		1.30	0.22	5.00	10.47	1.81	20.00	18.22	3.14	30.00	2.57	0.45	20.00	
24.08.2026		0.38	0.07	5.00	7.71	1.39	20.00	11.77	2.10	30.00	1.51	0.27	20.00	
25.08.2026		0.55	0.10	5.00	8.70	1.59	20.00	9.77	1.80	30.00	1.32	0.25	20.00	
26.08.2026		1.63	0.28	5.00	8.73	1.53	20.00	11.74	2.07	30.00	2.61	0.48	20.00	
27.08.2026		2.95	0.53	5.00	7.66	1.37	20.00	11.90	2.11	30.00	1.63	0.29	20.00	
28.08.2026		2.89	0.51	5.00	4.36	0.77	20.00	11.06	1.96	30.00	1.52	0.27	20.00	
29.08.2026		1.71	0.30	5.00	4.09	0.73	20.00	9.30	1.68	30.00	1.71	0.31	20.00	
30.08.2026		2.33	0.41	5.00	5.86	1.04	20.00	12.24	2.16	30.00	1.63	0.29	20.00	
31.08.2026		3.14	0.55	5.00	5.42	0.95	20.00	13.49	2.35	30.00	1.81	0.32	20.00	
MAV Average/ Sum	31 Stat.	1.30	0.22	5.00	4.56	0.78	20.00	8.22	1.41	30.00	1.99	0.35	20.00	
Availability in %		100.0 %	100.0 %	100.0 %	100.0 %	100.0 %	100.0 %	100.0 %	100.0 %	100.0 %	100.0 %	100.0 %	100.0 %	
DAV Min (steady state)		0.30	0.03	5.00	0.59	0.10	20.00	1.62	0.23	30.00	1.19	0.13	20.00	
Time		07.08.2026	03.08.2026	01.08.2026	16.08.2026	16.08.2026	01.08.2026	16.08.2026	09.08.2026	01.08.2026	09.08.2026	03.08.2026	01.08.2026	
DAV Max (steady state)		3.65	0.60	5.00	10.47	1.81	20.00	19.10	3.15	30.00	3.26	0.58	20.00	
Time		18.08.2026	18.08.2026	01.08.2026	23.08.2026	23.08.2026	01.08.2026	18.08.2026	18.08.2026	01.08.2026	17.08.2026	17.08.2026	01.08.2026	

Operation Hours: 718.0, Steady Op Hours: 669.0, Availability O2: 100.0 %

Legend
 Letrije - 'S' ili; zimsko - 'W'
 status postrojenja: Stabilan rad - '1'; Zastoj - '-'; Pokretanje - 'SU'; Zaustavljanje - 'SD'
 status merjenja: Validno - '1'; Zamenska vrednost - 'S'; Održavanje - 'M'; Kvar - 'X'; Kalibracija - 'C'; Iznad validnog opsega kalibracije - 'P'; Greška - 'F'; Iznad opsega merjenja - 'O'; Ispod opsega merjenja - 'U'; Nema podataka - 'N'
 Usaglašenost sa GVE: >GVE - 'L'; >GVE+MN - 'I'; >GVE*1,2 - 'A'; >GVE*1,2+MN - 'a'; >2*GVE - 'B'; >2*GVE+MN - 'b'; Dnevna važeća srednja vrednost>GVE - 'T'; Dnevna važeća srednja vrednost>GVE+MN - 't'
 MN: HF= 1 mg/m³; HCl=6 mg/m³; NH3=10 mg/m³

Date	Block Flag	O2	Sadržaj vlage	T	P	Protok	Kolic. Otp. gasa	
		%	%	°C	hPa	km³/h	km³	
01.08.2026		20.78	15.31	56.30	1000.84	170.49	4091.86	
02.08.2026		20.97	12.00	54.99	1001.15	180.75	4338.08	
03.08.2026		21.79	6.97	39.48	1001.92	75.90	1631.83	
04.08.2026		19.62	8.19	44.25	1002.70	200.07	4701.57	
05.08.2026		20.54	9.07	46.50	1002.19	195.84	4700.04	
06.08.2026		20.96	9.16	46.75	1001.46	192.16	4611.85	
07.08.2026		21.01	10.61	48.30	999.98	191.99	4607.73	
08.08.2026		21.62	10.58	48.16	1004.03	193.70	4648.94	
09.08.2026		22.64	6.41	37.49	1004.70	109.94	1814.04	
10.08.2026		22.64	13.46	52.83	1003.28	174.11	4178.56	
11.08.2026		22.46	15.00	55.39	1003.23	168.53	4044.75	
12.08.2026		21.77	15.29	56.15	1008.43	171.65	4119.72	
13.08.2026		21.47	15.05	55.66	1010.03	175.22	4205.39	
14.08.2026		21.51	14.98	55.51	1006.73	174.03	4176.65	
15.08.2026		21.47	15.30	55.94	1004.09	171.67	4119.98	
16.08.2026		21.77	14.73	54.74	1001.34	172.37	4136.85	
17.08.2026		21.22	13.75	52.41	997.27	175.04	4201.07	
18.08.2026		21.12	17.33	58.09	999.38	164.96	3959.12	
19.08.2026		22.37	16.85	57.00	999.77	166.68	4000.44	
20.08.2026		22.38	16.17	56.92	999.02	168.04	4033.00	
21.08.2026		22.24	12.98	49.62	998.18	178.76	2860.09	
22.08.2026		21.79	15.06	54.80	1000.41	171.66	3862.27	
23.08.2026		22.04	15.01	54.15	1006.44	173.17	4069.40	
24.08.2026		22.04	12.74	51.91	1004.76	178.54	4106.33	
25.08.2026		22.54	9.98	46.60	999.87	186.64	4479.35	
26.08.2026		20.31	12.98	51.56	1002.39	177.94	4270.63	
27.08.2026		22.10	12.71	52.24	1003.81	178.22	4277.19	
28.08.2026		22.37	13.09	52.61	1002.06	176.91	4245.78	
29.08.2026		22.12	12.01	49.76	1001.40	180.79	3525.38	
30.08.2026		22.52	13.32	52.53	1002.80	176.58	4237.97	
31.08.2026		22.06	13.86	53.69	1000.51	174.49	4187.81	
MAV Average/ Sum	31 Stat.	21.69	12.90	51.69	1002.39	172.48	124443.67	
Availability in %		100.0 %	100.0 %	100.0 %	100.0 %	100.0 %	100.0 %	
DAV Min (steady state)		19.62	6.41	37.49	997.27	75.90	1631.83	
Time		04.08.2026	09.08.2026	09.08.2026	17.08.2026	03.08.2026	03.08.2026	
DAV Max (steady state)		22.64	17.33	58.09	1010.03	200.07	4701.57	
Time		09.08.2026	18.08.2026	18.08.2026	13.08.2026	04.08.2026	04.08.2026	

Operation Hours: 718.0, Steady Op Hours: 669.0, Availability O2: 100.0 %

Legend
 Letnje - 'S' ili; zimsko - 'W'
 status postrojenja: Stabilan rad - '1'; Zastoj - '-'; Pokretanje - 'SU'; Zaustavljanje - 'SD'
 status merjenja: Validno - '1'; Zamenska vrednost - 'S'; Održavanje - 'M'; Kvar - 'X'; Kalibracija - 'C'; Iznad validnog opsega kalibracije - 'P'; Greška - 'F'; Iznad opsega merjenja - 'O'; Ispod opsega merjenja - 'U'; Nema podataka - 'N'
 Usaglašenost sa GVE: >GVE - 'L'; >GVE+MN - '1'; >GVE*1,2 - 'A'; >GVE*1,2-MN - 'a'; >2*GVE - 'B'; >2*GVE+MN - 'b'; Dnevna važeća srednja vrednost>GVE - 'T'; Dnevna važeća srednja vrednost>GVE+MN - 't'
 MN: HF= 1 mg/m³; HCl=6 mg/m³; NH3=10 mg/m³

Created on/ at 1.9.2026 / 00:03, created according to ÖNORM M9412:2008 (EmiProtocol Version V 6.5, Parameter Version V1)