

Date	Block Flag	HF			HCl			NH3			Prasina			
		mg/Nm³	kg/h	Limit	mg/Nm³	kg/h	Limit	mg/Nm³	kg/h	Limit	mg/Nm³	kg/h	Limit	
01.09.2026		1.45	0.25	5.00	3.45	0.63	20.00	11.99	2.17	30.00	1.77	0.33	20.00	
02.09.2026		3.07	0.55	5.00	3.31	0.59	20.00	13.25	2.38	30.00	2.14	0.39	20.00	
03.09.2026		1.92	0.34	5.00	2.52	0.44	20.00	10.39	1.83	30.00	1.80	0.32	20.00	
04.09.2026		2.62	0.45	5.00	2.20	0.38	20.00	11.97	2.06	30.00	2.52	0.43	20.00	
05.09.2026		2.45	0.41	5.00	4.28	0.73	20.00	11.88	2.01	30.00	1.88	0.32	20.00	
06.09.2026		1.56	0.27	5.00	4.43	0.81	20.00	8.87	1.58	30.00	1.91	0.35	20.00	
07.09.2026		2.07	0.38	5.00	5.65	1.04	20.00	9.18	1.69	30.00	1.49	0.28	20.00	
08.09.2026		3.33	0.59	5.00	8.09	1.44	20.00	11.67	2.08	30.00	1.59	0.28	20.00	
09.09.2026		2.73	0.48	5.00	8.06	1.41	20.00	11.46	2.01	30.00	1.49	0.26	20.00	
10.09.2026		3.26	0.55	5.00	1.70	0.29	20.00	7.35	1.24	30.00	1.62	0.27	20.00	
11.09.2026		2.04	0.36	5.00	5.02	0.91	20.00	11.09	2.00	30.00	1.88	0.34	20.00	
12.09.2026		1.97	0.34	5.00	4.06	0.70	20.00	11.96	2.05	30.00	1.84	0.32	20.00	
13.09.2026		0.92	0.17	5.00	3.49	0.63	20.00	9.74	1.76	30.00	2.17	0.39	20.00	
14.09.2026		1.96	0.35	5.00	3.45	0.62	20.00	9.23	1.63	30.00	2.17	0.38	20.00	
15.09.2026		2.91	0.52	5.00	6.96	1.25	20.00	10.77	1.93	30.00	1.63	0.29	20.00	
16.09.2026		2.46	0.44	5.00	8.26	1.49	20.00	10.04	1.81	30.00	1.48	0.26	20.00	
17.09.2026		3.09	0.55	5.00	7.88	1.41	20.00	11.89	2.12	30.00	1.54	0.28	20.00	
18.09.2026		1.60	0.29	5.00	6.32	1.15	20.00	11.23	2.04	30.00	1.35	0.25	20.00	
19.09.2026		0.33	0.07	5.00	1.20	0.24	20.00	2.42	0.47	30.00	0.97	0.19	20.00	
20.09.2026		0.38	0.07	5.00	5.56	1.05	20.00	2.86	0.54	30.00	1.01	0.19	20.00	
21.09.2026		0.37	0.07	5.00	4.84	0.92	20.00	2.57	0.49	30.00	1.00	0.19	20.00	
22.09.2026		0.36	0.07	5.00	3.99	0.76	20.00	2.17	0.41	30.00	1.03	0.20	20.00	
23.09.2026		0.36	0.07	5.00	2.75	0.52	20.00	1.99	0.38	30.00	1.04	0.20	20.00	
24.09.2026		0.36	0.07	5.00	3.16	0.62	20.00	1.45	0.27	30.00	1.05	0.20	20.00	
25.09.2026														
26.09.2026														
27.09.2026														
28.09.2026														
29.09.2026														
30.09.2026														
MAV Average/ Sum		24 Stat.												
Availability in %		100.0 %	100.0 %	100.0 %	100.0 %	100.0 %	100.0 %	100.0 %	100.0 %	100.0 %	100.0 %	100.0 %	100.0 %	
DAV Min (steady state)		0.33	0.07	5.00	1.20	0.24	20.00	1.45	0.27	30.00	0.97	0.19	20.00	
Time		19.09.2026	19.09.2026	01.09.2026	19.09.2026	19.09.2026	01.09.2026	24.09.2026	24.09.2026	01.09.2026	19.09.2026	19.09.2026	01.09.2026	
DAV Max (steady state)		3.33	0.59	5.00	8.26	1.49	20.00	13.25	2.38	30.00	2.52	0.43	20.00	
Time		08.09.2026	08.09.2026	01.09.2026	16.09.2026	16.09.2026	01.09.2026	02.09.2026	02.09.2026	01.09.2026	04.09.2026	04.09.2026	01.09.2026	

Operation Hours: 516.0, Steady Op Hours: 497.0, Availability O2: 100.0 %

Legend
 Letnje - 'S' ili; zimsko - 'W'
 status postrojenja: Stabilan rad - '1'; Zastoj - '-'; Pokretanje - 'SU'; Zaustavljanje - 'SD'
 status merjenja: Validno - '1'; Zamenska vrednost - 'S'; Održavanje - 'M'; Kvar - 'X'; Kalibracija - 'C'; Iznad validnog opsega kalibracije - 'P'; Greška - 'F'; Iznad opsega merjenja - 'O'; Ispod opsega merjenja - 'U'; Nema podataka - 'N'
 Usaglašenost sa GVE: >GVE - 'L'; >GVE+MN - 'I'; >GVE*1.2 - 'A'; >GVE*1.2+MN - 'a'; >2*GVE - 'B'; >2*GVE+MN - 'b'; Dnevna važeća srednja vrednost>GVE - 'T'; Dnevna važeća srednja vrednost>GVE+MN - 't'
 MN: HF= 1 mg/m³; HCl=6 mg/m³; NH3=10 mg/m³

Date	Block Flag	O2	Sadržaj vlage	T	P	Protok	Kolic. Otp. gasa	
		%	%	°C	hPa	km³/h	km³	
01.09.2026		20.45	10.66	46.17	1003.11	186.29	1862.87	
02.09.2026		21.98	12.30	51.27	1006.70	180.04	4320.88	
03.09.2026		22.28	13.75	53.58	1005.57	175.57	4125.81	
04.09.2026		20.49	14.58	54.54	1005.93	173.57	4078.78	
05.09.2026		20.57	15.98	56.71	1004.06	169.20	4060.82	
06.09.2026		21.50	12.41	50.49	1011.56	181.36	4352.72	
07.09.2026		22.39	10.92	48.67	1011.32	185.22	4445.20	
08.09.2026		22.80	12.73	51.66	1004.59	178.58	4285.83	
09.09.2026		22.85	13.42	52.62	997.81	175.42	4210.00	
10.09.2026		22.11	15.81	56.48	1002.58	169.33	4063.98	
11.09.2026		23.21	11.34	52.62	1004.70	180.76	4338.28	
12.09.2026		20.31	15.37	55.71	1009.97	171.81	4123.38	
13.09.2026		21.19	12.19	50.89	1009.19	180.84	4068.81	
14.09.2026		21.19	13.46	52.77	1008.42	177.03	4248.69	
15.09.2026		21.64	12.51	51.53	1008.39	179.64	4311.41	
16.09.2026		22.04	12.18	50.79	1003.70	179.91	4317.97	
17.09.2026		22.25	12.10	51.56	1000.52	179.14	4209.76	
18.09.2026		22.35	11.25	48.50	1002.20	182.93	1280.51	
19.09.2026		20.57	7.49	41.62	1009.86	196.20	3041.06	
20.09.2026		21.43	9.41	46.16	1010.08	189.44	4546.67	
21.09.2026		21.95	9.14	45.55	1009.07	190.21	4565.05	
22.09.2026		22.02	8.70	44.36	1008.98	191.78	4314.99	
23.09.2026		22.22	9.13	45.44	1010.32	190.45	4475.60	
24.09.2026		22.07	8.65	43.52	1009.02	192.60	1637.12	
25.09.2026								
26.09.2026								
27.09.2026								
28.09.2026								
29.09.2026								
30.09.2026								
MAV Average/ Sum	24 Stat.							
Availability in %		100.0 %	100.0 %	100.0 %	100.0 %	100.0 %	100.0 %	
DAV Min (steady state)		20.31	7.49	41.62	997.81	169.20	1280.51	
Time		12.09.2026	19.09.2026	19.09.2026	09.09.2026	05.09.2026	18.09.2026	
DAV Max (steady state)		23.21	15.98	56.71	1011.56	196.20	4565.05	
Time		11.09.2026	05.09.2026	05.09.2026	06.09.2026	19.09.2026	21.09.2026	

Operation Hours: 516.0, Steady Op Hours: 497.0, Availability O2: 100.0 %

Legend
 Letnje - 'S' ili; zimsko - 'W'
 status postrojenja: Stabilan rad - '1'; Zastoj - '0'; Pokretanje - 'SU'; Zaustavljanje - 'SD'
 status merjenja: Validno - '1'; Zamenska vrednost - 'S'; Održavanje - 'M'; Kvar - 'X'; Kalibracija - 'C'; Iznad validnog opsega kalibracije - 'P'; Greška - 'F'; Iznad opsega merjenja - 'O'; Ispod opsega merjenja - 'U'; Nema podataka - 'N'
 Usaglasenost sa GVE: >GVE - 'L'; >GVE+MN - 'I'; >GVE*1,2 - 'A'; >GVE*1,2+MN - 'a'; >2*GVE - 'B'; >2*GVE+MN - 'b'; Dnevna važeća srednja vrednost>GVE - 'T'; Dnevna važeća srednja vrednost>GVE+MN - 't'
 MN: HF= 1 mg/m³; HCl=6 mg/m³; NH3=10 mg/m³

Created on/ at 25.9.2026./ 00:02, created according to ÖNORM M9412:2008 (EmiProtocol Version V 6.5, Parameter Version V1)